

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P685267

Luminaire Tested: **LX6C90D010 EX6909030 6LBMLI**

Issue Date: 2/15/2022

Test Information

Test Method: LM-79-08
Report Number: P685267
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P205108)
Test Lab: INNOVATION CENTER
Issue Date: 2/15/2022
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LX6C90D010 EX6909030 6LBMLI
Description: 6 INCH 9000 LUMEN PORTFOLIO LED DOWNLIGHT WITH, 3000K, 90CRI LEDS
AND 6LBM TRIM WITH LI FINISH
Light Source: -
Ballast/Driver: -

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 8666.0 lumens
Efficiency: N/A
Efficacy: 89.2 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 97.1
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P685267

CATALOG NUMBER: LX6C90D010 EX6909030 6LBMLI

Luminous Intensity Polar Plot





TEST NUMBER: P685267

CATALOG NUMBER: LX6C90D010 EX6909030 6LBMLI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94			
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88			
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82			
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76			
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71			
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67			
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63			
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59			
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55			
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	594530
5°	588871
10°	558011
15°	506620
20°	447677
25°	387028
30°	302534
35°	185531
40°	95228
45°	37833
50°	12281
55°	4234
60°	3629
65°	2893
70°	1795
75°	2372
80°	0
85°	0



TEST NUMBER: P685267

CATALOG NUMBER: LX6C90D010 EX6909030 6LBMLI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	999.1	11.5
10°-20°	2487.3	28.7
20°-30°	2891.4	33.4
30°-40°	1770.6	20.4
40°-50°	439.7	5.1
50°-60°	51.3	0.6
60°-70°	19.2	0.2
70°-80°	7.3	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	6377.8	73.6
0°-40°	8148.4	94.0
0°-60°	8639.4	99.7
0°-90°	8666.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	8666.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	10845	
5°	10701	999
15°	8927	2487
25°	6398	2891
35°	2772	1771
45°	488	440
55°	44	51
65°	22	19
75°	11	7
85°	0	0
90°	0	



TEST NUMBER: P685267

CATALOG NUMBER: LX6C90D010 EX6909030 6LBMLI

CANDELA DISTRIBUTION (FULL):

	0°
0°	10845.1
2.5°	10833.9
5°	10701.0
7.5°	10412.6
10°	10024.3
12.5°	9514.4
15°	8926.6
17.5°	8294.6
20°	7673.8
22.5°	7052.5
25°	6398.5
27.5°	5644.4
30°	4779.3
32.5°	3770.2
35°	2772.3
37.5°	1951.6
40°	1330.7
42.5°	831.5
45°	488.0
47.5°	277.3
50°	144.0
52.5°	66.6
55°	44.3
57.5°	33.1
60°	33.1
62.5°	22.3
65°	22.3
67.5°	11.2
70°	11.2
72.5°	11.2
75°	11.2
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By 670246072 / DESKTOP-50001EG





— 0°-180°







(END OF REPORT)