

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P135164

Luminaire Tested: **LD6A10D010TE ERN6A10927 6LN1H**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P135164
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P23370)
Test Lab: INNOVATION CENTER P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LD6A10D010TE ERN6A10927 6LN1H
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
NARROW DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
Light Source: (1) HIGH LUMEN LED 2700K
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 888.6 lumens
Efficiency: N/A
Efficacy: 63.5 lumens/watt
Spacing Criteria (0/90/45): 0.74 / 0.74 / 0.84
Luminous Opening: Circular (Dia: 0.46' x H: 0')
CIE Type: Direct


Input Watts (W): 14
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P135164

CATALOG NUMBER: LD6A10D010TE ERN6A10927 6LN1H

Luminous Intensity Polar Plot





TEST NUMBER: P135164

CATALOG NUMBER: LD6A10D010TE ERN6A10927 6LN1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93			
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87			
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80			
4	97	89	84	80	95	88	83	79	86	82	78	84	80	77	82	79	76	75			
5	92	84	78	73	90	83	77	73	81	76	72	79	75	72	78	74	71	70			
6	87	78	72	68	86	78	72	68	76	71	67	75	70	67	73	69	66	65			
7	83	74	68	63	82	73	67	63	72	67	63	71	66	63	69	65	62	61			
8	79	69	63	59	78	69	63	59	68	63	59	67	62	59	66	62	58	57			
9	75	66	60	56	74	65	59	56	64	59	55	63	59	55	62	58	55	54			
10	72	62	56	52	71	62	56	52	61	56	52	60	55	52	59	55	52	51			

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	76462
5°	73964
10°	65942
15°	57478
20°	49780
25°	42709
30°	35851
35°	25160
40°	13098
45°	6237
50°	3268
55°	1774
60°	1227
65°	803
70°	591
75°	529
80°	376
85°	0



TEST NUMBER: P135164

CATALOG NUMBER: LD6A10D010TE ERN6A10927 6LN1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	103.4	11.6
10°-20°	237.8	26.8
20°-30°	272.1	30.6
30°-40°	193.9	21.8
40°-50°	58.6	6.6
50°-60°	15.2	1.7
60°-70°	5.6	0.6
70°-80°	1.9	0.2
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	613.3	69.0
0°-40°	807.1	90.8
0°-60°	880.9	99.1
0°-90°	888.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	888.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1172	
5°	1129	103
15°	851	238
25°	593	272
35°	316	194
45°	68	59
55°	16	15
65°	5	6
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P135164

CATALOG NUMBER: LD6A10D010TE ERN6A10927 6LN1H

CANDELA DISTRIBUTION (FULL):

	0°
0°	1172.0
2.5°	1158.5
5°	1129.4
7.5°	1071.2
10°	995.4
12.5°	919.6
15°	851.0
17.5°	784.5
20°	717.0
22.5°	653.5
25°	593.3
27.5°	536.1
30°	475.9
32.5°	403.2
35°	315.9
37.5°	226.5
40°	153.8
42.5°	101.8
45°	67.6
47.5°	46.7
50°	32.2
52.5°	20.7
55°	15.6
57.5°	11.5
60°	9.4
62.5°	7.3
65°	5.2
67.5°	4.1
70°	3.1
72.5°	2.1
75°	2.1
77.5°	1.0
80°	1.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)