

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P788968

Luminaire Tested: LER6D10D010-EC6DR300210IC9035-6LBDP1H

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P788968
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER6D10D010-EC6DR300210IC9035-6LBDP1H
Description: 6 INCH ROUND DEEP 45° CUTOFF SEMI-SPECULAR CLEAR TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1870.1 lumens
Efficiency: N/A
Efficacy: 159.8 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct


Input Watts (W): 11.7
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P788968
CATALOG NUMBER: LER6D10D010-EC6DR300210IC9035-6LBDP1H

Luminous Intensity Polar Plot





TEST NUMBER: P788968

CATALOG NUMBER: LER6D10D010-EC6DR300210IC9035-6LBDP1H

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96																			
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92																			
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89																			
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85																			
5	100	94	89	86	98	93	89	86	91	88	85	90	86	84	88	86	83	82																			
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79																			
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77																			
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74																			
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72																			
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69																			

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	460263	460263	460263
5°	447054	446531	447077
10°	387214	384486	387121
15°	252636	251281	250021
20°	125629	130337	125458
25°	63283	71357	61982
30°	25340	27603	22078
35°	11755	11260	9438
40°	5076	5636	4776
45°	3583	4438	3616
50°	1227	3239	1298
55°	707	1334	747
60°	490	582	490
65°	326	326	326
70°	201	134	201
75°	0	89	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°
 Vertical Angle: 45°
 Luminance: 4438 cd/sqm



TEST NUMBER: P788968

CATALOG NUMBER: LER6D10D010-EC6DR300210IC9035-6LBDP1H

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	528.8	28.3
10°-20°	851.6	45.5
20°-30°	368.0	19.7
30°-40°	83.9	4.5
40°-50°	28.8	1.5
50°-60°	7.0	0.4
60°-70°	1.8	0.1
70°-80°	0.2	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1748.3	93.5
0°-40°	1832.2	98.0
0°-60°	1868.0	99.9
0°-90°	1870.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1870.1	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	6013	6013	6013	6013	6013	
5°	5818	5813	5812	5824	5819	529
15°	3188	3150	3171	3161	3155	854
25°	749	778	845	758	734	359
35°	126	128	120	120	101	85
45°	33	41	41	41	33	23
55°	5	6	10	6	6	5
65°	2	2	2	2	2	2
75°	0	0	0	0	0	0
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P788968

CATALOG NUMBER: LER6D10D010-EC6DR300210IC9035-6LBDP1H

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	6013.1	6013.1	6013.1	6013.1	6013.1
2.5°	5973.3	5969.2	5971.5	5974.5	5975.7
5°	5818.3	5812.7	5811.5	5823.6	5818.6
7.5°	5505.7	5497.7	5485.6	5513.0	5538.7
10°	4981.9	4973.1	4946.8	4959.8	4980.7
12.5°	4208.7	4180.1	4179.5	4220.8	4215.2
15°	3188.1	3149.8	3171.0	3160.7	3155.1
17.5°	2143.9	2129.2	2157.5	2148.9	2112.0
20°	1542.3	1546.1	1600.1	1573.0	1540.2
22.5°	1125.4	1139.3	1203.3	1133.4	1107.7
25°	749.3	777.6	844.9	757.8	733.9
27.5°	460.8	473.8	542.0	454.9	442.0
30°	286.7	280.2	312.3	268.1	249.8
32.5°	188.1	179.8	190.1	170.6	155.9
35°	125.8	128.4	120.5	119.6	101.0
37.5°	78.5	90.3	79.7	85.0	64.9
40°	50.8	65.5	56.4	62.3	47.8
42.5°	41.6	50.5	46.4	49.3	42.5
45°	33.1	41.0	41.0	41.0	33.4
47.5°	18.3	27.5	35.1	28.0	19.5
50°	10.3	13.9	27.2	14.5	10.9
52.5°	7.1	8.0	18.6	8.3	7.4
55°	5.3	5.6	10.0	5.9	5.6
57.5°	4.1	4.4	5.3	4.4	4.1
60°	3.2	3.2	3.8	3.5	3.2
62.5°	2.4	2.4	2.7	2.4	2.4
65°	1.8	1.8	1.8	1.8	1.8
67.5°	0.9	1.2	1.2	1.2	1.2
70°	0.9	0.6	0.6	0.6	0.9
72.5°	0.6	0.3	0.3	0.3	0.3
75°	0.0	0.0	0.3	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)