

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P791099

Luminaire Tested: LER6D25D010-EC6DR6520359027-6LBS1B

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P791099  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LER6D25D010-EC6DR6520359027-6LBS1B  
Description: 6 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 65° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 4104.6 lumens  
Efficiency: N/A  
Efficacy: 163.5 lumens/watt  
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96  
Luminous Opening: Circular (Dia: 0.48' x H: 0')  
CIE Type: Direct


Input Watts (W): 25.1  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



Downlight

TEST NUMBER: P791099  
CATALOG NUMBER: LER6D25D010-EC6DR6520359027-6LBS1B

### Luminous Intensity Polar Plot





TEST NUMBER: P791099

CATALOG NUMBER: LER6D25D010-EC6DR6520359027-6LBS1B

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93	93	93	93
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85	85	85	85
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78	78	78	78
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72	72	72	72
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66	66	66	66
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61	61	61	61
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56	56	56	56
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52	52	52	52
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49	49	49	49
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46	46	46	46

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	217665
5°	217113
10°	216931
15°	210240
20°	191397
25°	166794
30°	138722
35°	109920
40°	79336
45°	50119
50°	26122
55°	13889
60°	7289
65°	4008
70°	1691
75°	1850
80°	1278
85°	1072

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 50119 cd/sqm



TEST NUMBER: P791099

CATALOG NUMBER: LER6D25D010-EC6DR6520359027-6LBS1B

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	352.4	8.6
10°-20°	965.1	23.5
20°-30°	1179.7	28.7
30°-40°	957.2	23.3
40°-50°	477.0	11.6
50°-60°	133.0	3.2
60°-70°	30.2	0.7
70°-80°	7.9	0.2
80°-90°	2.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2497.3	60.8
0°-40°	3454.5	84.2
0°-60°	4064.5	99.0
0°-90°	4104.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4104.6	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3727	
5°	3703	352
15°	3477	965
25°	2588	1180
35°	1542	957
45°	607	477
55°	136	133
65°	29	30
75°	8	8
85°	2	2
90°	0	



TEST NUMBER: P791099

CATALOG NUMBER: LER6D25D010-EC6DR6520359027-6LBS1B

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	3726.9
2.5°	3724.1
5°	3703.3
7.5°	3691.3
10°	3657.9
12.5°	3589.9
15°	3477.1
17.5°	3300.8
20°	3079.5
22.5°	2840.7
25°	2588.3
27.5°	2318.3
30°	2057.0
32.5°	1799.1
35°	1541.7
37.5°	1284.8
40°	1040.6
42.5°	811.6
45°	606.8
47.5°	422.8
50°	287.5
52.5°	198.3
55°	136.4
57.5°	92.0
60°	62.4
62.5°	43.3
65°	29.0
67.5°	14.8
70°	9.9
72.5°	9.3
75°	8.2
77.5°	5.5
80°	3.8
82.5°	2.7
85°	1.6
87.5°	1.1
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)