

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P791125

Luminaire Tested: LER6D25D010-EC6DR6520359040-6LBS1LI

Issue Date: 2/2/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P791125  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/2/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LER6D25D010-EC6DR6520359040-6LBS1LI  
Description: 6 INCH ROUND SHALLOW SPECULAR CLEAR TRIM, WITH 65° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 5199.8 lumens  
Efficiency: N/A  
Efficacy: 207.2 lumens/watt  
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96  
Luminous Opening: Circular (Dia: 0.48' x H: 0')  
CIE Type: Direct

Input Watts (W): 25.1  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight

TEST NUMBER: P791125

CATALOG NUMBER: LER6D25D010-EC6DR6520359040-6LBS1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P791125  
 CATALOG NUMBER: LER6D25D010-EC6DR6520359040-6LBS1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	93			93																
2	107	102	97	94	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85																
3	101	94	88	84	99	92	87	83	90	86	82	87	84	81	85	82	80	78			78																
4	95	87	81	76	93	86	80	76	84	79	75	82	77	74	80	76	73	72			72																
5	90	81	74	70	88	80	74	69	78	73	69	76	72	68	75	71	68	66			66																
6	85	75	69	64	83	74	68	64	73	67	63	71	67	63	70	66	62	61			61																
7	80	70	64	59	79	69	63	59	68	63	59	67	62	58	66	61	58	56			56																
8	76	66	59	55	75	65	59	55	64	58	54	63	58	54	62	57	54	52			52																
9	72	61	55	51	71	61	55	51	60	54	51	59	54	50	58	54	50	49			49																
10	68	58	52	47	67	57	51	47	57	51	47	56	51	47	55	50	47	46			46																

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	275742
5°	275043
10°	274807
15°	266338
20°	242468
25°	211297
30°	175739
35°	139245
40°	100501
45°	63491
50°	33091
55°	17595
60°	9239
65°	5086
70°	2135
75°	2347
80°	1648
85°	1407

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 45°  
 Luminance: 63491 cd/sqm



TEST NUMBER: P791125

CATALOG NUMBER: LER6D25D010-EC6DR6520359040-6LBS1LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	446.5	8.6
10°-20°	1222.6	23.5
20°-30°	1494.5	28.7
30°-40°	1212.6	23.3
40°-50°	604.2	11.6
50°-60°	168.6	3.2
60°-70°	38.3	0.7
70°-80°	10.0	0.2
80°-90°	2.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3163.6	60.8
0°-40°	4376.2	84.2
0°-60°	5149.0	99.0
0°-90°	5199.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5199.8	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	4721	
5°	4691	446
15°	4405	1223
25°	3279	1494
35°	1953	1213
45°	769	604
55°	173	169
65°	37	38
75°	10	10
85°	2	3
90°	0	



TEST NUMBER: P791125

CATALOG NUMBER: LER6D25D010-EC6DR6520359040-6LBS1LI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	4721.3
2.5°	4717.8
5°	4691.4
7.5°	4676.2
10°	4633.8
12.5°	4547.8
15°	4404.9
17.5°	4181.5
20°	3901.2
22.5°	3598.7
25°	3278.9
27.5°	2936.8
30°	2605.9
32.5°	2279.1
35°	1953.0
37.5°	1627.6
40°	1318.2
42.5°	1028.2
45°	768.7
47.5°	535.6
50°	364.2
52.5°	251.2
55°	172.8
57.5°	116.6
60°	79.1
62.5°	54.8
65°	36.8
67.5°	18.7
70°	12.5
72.5°	11.8
75°	10.4
77.5°	6.9
80°	4.9
82.5°	3.5
85°	2.1
87.5°	1.4
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)