

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269



Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P791145

Luminaire Tested: LER6D25D010-EC6DR7020359027-6LBDP1LI

Issue Date: 2/5/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P791145  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-73)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/5/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LER6D25D010-EC6DR7020359027-6LBDDP1LI  
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR CLEAR TRIM, WITH 70° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 2700K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 5080.0 lumens  
Efficiency: N/A  
Efficacy: 202.4 lumens/watt  
Spacing Criteria (0/90/45): 0.88 / 0.88 / 0.82  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct


Input Watts (W): 25.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT



Downlight

TEST NUMBER: P791145  
CATALOG NUMBER: LER6D25D010-EC6DR7020359027-6LBDP1LI

### Luminous Intensity Polar Plot





TEST NUMBER: P791145

CATALOG NUMBER: LER6D25D010-EC6DR7020359027-6LBDP1LI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	106	103	110	107	104	102	103	101	99	99	97	96	95	94	93	91																			
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	87	85	83																			
3	100	92	87	82	98	91	86	81	88	84	80	86	82	79	83	80	78	76																			
4	94	86	80	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70																			
5	89	80	74	69	87	79	73	69	77	72	68	75	71	67	74	70	67	65																			
6	85	75	68	64	83	74	68	64	73	67	63	71	66	63	70	66	62	61																			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57																			
8	77	66	60	56	75	66	60	56	65	59	55	64	59	55	63	58	55	53																			
9	73	63	57	52	72	62	56	52	61	56	52	60	55	52	60	55	52	50																			
10	70	59	53	49	69	59	53	49	58	53	49	57	52	49	57	52	49	48																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	624021
5°	605478
10°	588603
15°	580880
20°	542425
25°	407491
30°	288069
35°	102038
40°	53657
45°	57141
50°	59170
55°	60290
60°	60662
65°	59385
70°	56033
75°	51925
80°	46058
85°	37358

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 57.5°  
 Luminance: 60680 cd/sqm



TEST NUMBER: P791145

CATALOG NUMBER: LER6D25D010-EC6DR7020359027-6LBDP1LI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	520.7	10.3
10°-20°	1428.3	28.1
20°-30°	1573.0	31.0
30°-40°	601.0	11.8
40°-50°	283.8	5.6
50°-60°	282.1	5.6
60°-70°	225.9	4.4
70°-80°	129.8	2.6
80°-90°	35.3	0.7
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3522.0	69.3
0°-40°	4123.0	81.2
0°-60°	4688.9	92.3
0°-90°	5080.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5080.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	5711	
5°	5520	521
15°	5135	1428
25°	3380	1573
35°	765	601
45°	370	284
55°	316	282
65°	230	226
75°	123	130
85°	30	35
90°	0	



TEST NUMBER: P791145

CATALOG NUMBER: LER6D25D010-EC6DR7020359027-6LBDP1LI

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	5711.3
2.5°	5651.7
5°	5520.5
7.5°	5411.1
10°	5305.3
12.5°	5215.8
15°	5135.3
17.5°	4940.9
20°	4665.1
22.5°	4070.1
25°	3380.1
27.5°	2942.5
30°	2283.3
32.5°	1474.9
35°	765.0
37.5°	413.2
40°	376.2
42.5°	373.5
45°	369.8
47.5°	361.7
50°	348.1
52.5°	332.8
55°	316.5
57.5°	298.4
60°	277.6
62.5°	254.1
65°	229.7
67.5°	202.6
70°	175.4
72.5°	148.3
75°	123.0
77.5°	96.8
80°	73.2
82.5°	51.5
85°	29.8
87.5°	11.8
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)