

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P792651

Luminaire Tested: LER6D40BD010-EC6DR6540509035-6LBS1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P792651
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-147)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER6D40BD010-EC6DR6540509035-6LBS1B
Description: 6 INCH ROUND SHALLOW SPECULAR BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3874.2 lumens
Efficiency: N/A
Efficacy: 110.1 lumens/watt
Spacing Criteria (0/90/45): 0.95 / 0.95 / 0.96
Luminous Opening: Circular (Dia: 0.48' x H: 0')
CIE Type: Direct


Input Watts (W): 35.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P792651
CATALOG NUMBER: LER6D40BD010-EC6DR6540509035-6LBS1B

Luminous Intensity Polar Plot





TEST NUMBER: P792651

CATALOG NUMBER: LER6D40BD010-EC6DR6540509035-6LBS1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	113	110	107	105	111	108	105	103	104	102	100		100	99	97		97	95	94	93
2	107	102	97	94	105	100	96	92	97	93	90		94	91	88		91	89	87	85
3	101	94	88	84	99	92	87	83	90	86	82		87	84	81		85	82	80	78
4	95	87	81	76	93	86	80	76	84	79	75		82	77	74		80	76	73	72
5	90	81	74	70	88	80	74	69	78	73	69		76	72	68		75	71	68	66
6	85	75	69	64	83	74	68	64	73	67	63		71	67	63		70	66	62	61
7	80	70	64	59	79	69	63	59	68	63	59		67	62	58		66	61	58	56
8	76	66	59	55	75	65	59	55	64	58	54		63	58	54		62	57	54	52
9	72	61	55	51	71	61	55	51	60	54	51		59	54	50		58	54	50	49
10	68	58	52	47	67	57	51	47	57	51	47		56	51	47		55	50	47	46

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	205441
5°	204925
10°	204750
15°	198437
20°	180651
25°	157431
30°	130933
35°	103746
40°	74876
45°	47302
50°	24659
55°	13105
60°	6880
65°	3787
70°	1588
75°	1760
80°	1211
85°	1072

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 47302 cd/sqm



TEST NUMBER: P792651

CATALOG NUMBER: LER6D40BD010-EC6DR6540509035-6LBS1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	332.7	8.6
10°-20°	910.9	23.5
20°-30°	1113.5	28.7
30°-40°	903.4	23.3
40°-50°	450.2	11.6
50°-60°	125.6	3.2
60°-70°	28.5	0.7
70°-80°	7.4	0.2
80°-90°	1.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2357.1	60.8
0°-40°	3260.5	84.2
0°-60°	3836.3	99.0
0°-90°	3874.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3874.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3518	
5°	3495	333
15°	3282	911
25°	2443	1113
35°	1455	903
45°	573	450
55°	129	126
65°	27	29
75°	8	7
85°	2	2
90°	0	



TEST NUMBER: P792651

CATALOG NUMBER: LER6D40BD010-EC6DR6540509035-6LBS1B

CANDELA DISTRIBUTION (FULL):

	0°
0°	3517.6
2.5°	3515.0
5°	3495.4
7.5°	3484.0
10°	3452.5
12.5°	3388.4
15°	3281.9
17.5°	3115.5
20°	2906.6
22.5°	2681.3
25°	2443.0
27.5°	2188.1
30°	1941.5
32.5°	1698.1
35°	1455.1
37.5°	1212.7
40°	982.1
42.5°	766.1
45°	572.7
47.5°	399.1
50°	271.4
52.5°	187.1
55°	128.7
57.5°	86.8
60°	58.9
62.5°	40.8
65°	27.4
67.5°	14.0
70°	9.3
72.5°	8.8
75°	7.8
77.5°	5.2
80°	3.6
82.5°	2.6
85°	1.6
87.5°	1.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)