

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P792791

Luminaire Tested: LER6D45BD010-EC6DR3040509035-6LBDP1B

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P792791
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER6D45BD010-EC6DR3040509035-6LBDP1B
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR BLACK TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3895.9 lumens
Efficiency: N/A
Efficacy: 100.7 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct

Input Watts (W): 38.7
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P792791

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1B

Luminous Intensity Polar Plot





TEST NUMBER: P792791

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0													
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100						100													
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96						96													
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92						92													
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89						89													
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85						85													
5	100	94	89	86	98	93	89	86	91	88	85	90	86	84	88	86	83	82						82													
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79						79													
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77						77													
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74						74													
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72						72													
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69						69													

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	958882	958882	958882
5°	931350	930266	931403
10°	806692	801002	806505
15°	526328	523499	520868
20°	261717	271541	261367
25°	131836	148668	129134
30°	52783	57512	45987
35°	24482	23445	19651
40°	10572	11741	9952
45°	7458	9255	7523
50°	2560	6740	2715
55°	1481	2789	1561
60°	1041	1225	1041
65°	670	670	670
70°	403	269	403
75°	0	177	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°

Vertical Angle: 45°

Luminance: 9255 cd/sqm



TEST NUMBER: P792791

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1101.6	28.3
10°-20°	1774.1	45.5
20°-30°	766.6	19.7
30°-40°	174.7	4.5
40°-50°	60.0	1.5
50°-60°	14.7	0.4
60°-70°	3.8	0.1
70°-80°	0.4	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3642.3	93.5
0°-40°	3817.1	98.0
0°-60°	3891.7	99.9
0°-90°	3895.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3895.9	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	12527	12527	12527	12527	12527	
5°	12121	12110	12107	12132	12122	1102
15°	6642	6562	6606	6585	6573	1778
25°	1561	1620	1760	1579	1529	747
35°	262	268	251	249	210	178
45°	69	86	86	86	70	49
55°	11	12	21	12	12	11
65°	4	4	4	4	4	4
75°	0	0	1	0	0	1
85°	0	0	0	0	0	0
90°	0	0	0	0	0	0



TEST NUMBER: P792791

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1B

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	12527.3	12527.3	12527.3	12527.3	12527.3
2.5°	12444.2	12435.6	12440.5	12446.7	12449.2
5°	12121.3	12109.7	12107.2	12132.4	12122.0
7.5°	11470.0	11453.4	11428.2	11485.4	11538.9
10°	10378.9	10360.5	10305.7	10332.8	10376.5
12.5°	8768.1	8708.4	8707.2	8793.3	8781.6
15°	6641.9	6561.9	6606.2	6584.7	6573.0
17.5°	4466.5	4435.7	4494.8	4476.9	4400.0
20°	3213.0	3221.0	3333.6	3277.0	3208.7
22.5°	2344.6	2373.5	2506.9	2361.2	2307.7
25°	1561.0	1620.0	1760.3	1578.8	1529.0
27.5°	960.1	987.1	1129.2	947.8	920.7
30°	597.2	583.7	650.7	558.5	520.3
32.5°	391.8	374.6	396.1	355.5	324.7
35°	262.0	267.5	250.9	249.1	210.3
37.5°	163.6	188.2	166.1	177.1	135.3
40°	105.8	136.5	117.5	129.8	99.6
42.5°	86.7	105.2	96.6	102.7	88.6
45°	68.9	85.5	85.5	85.5	69.5
47.5°	38.1	57.2	73.2	58.4	40.6
50°	21.5	28.9	56.6	30.1	22.8
52.5°	14.8	16.6	38.7	17.2	15.4
55°	11.1	11.7	20.9	12.3	11.7
57.5°	8.6	9.2	11.1	9.2	8.6
60°	6.8	6.8	8.0	7.4	6.8
62.5°	4.9	4.9	5.5	4.9	4.9
65°	3.7	3.7	3.7	3.7	3.7
67.5°	1.8	2.5	2.5	2.5	2.5
70°	1.8	1.2	1.2	1.2	1.8
72.5°	1.2	0.6	0.6	0.6	0.6
75°	0.0	0.0	0.6	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)