

Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P792794

Luminaire Tested: LER6D45BD010-EC6DR3040509035-6LBDP1MW

Issue Date: 2/2/2024

Test Information

Test Method: LM-79-2019
Report Number: P792794
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-16)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/2/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER6D45BD010-EC6DR3040509035-6LBDP1MW
Description: 6 INCH ROUND DEEP 45° CUTOFF MATTE WHITE TRIM, WITH 30° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4316.7 lumens
Efficiency: N/A
Efficacy: 111.5 lumens/watt
Spacing Criteria (0/90/45): 0.52 / 0.52 / 0.49
Luminous Opening: Rectangular (W 0.38' x L: 0.38' x H: 0')
CIE Type: Direct

Input Watts (W): 38.7
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT




Downlight

TEST NUMBER: P792794

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1MW

Luminous Intensity Polar Plot





TEST NUMBER: P792794

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1MW

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	115	113	111	109	112	110	109	107	106	105	104	103	102	101	99	99	98	96																			
2	111	107	104	101	109	105	102	100	102	100	98	99	97	96	97	95	94	92																			
3	107	102	98	95	105	101	97	94	98	95	93	96	93	91	94	92	90	89																			
4	103	98	93	90	102	96	93	90	94	91	89	93	90	88	91	89	87	85																			
5	100	94	89	86	98	93	89	86	91	88	85	90	86	84	88	86	83	82																			
6	97	90	85	82	95	89	85	82	88	84	81	87	83	81	85	83	80	79																			
7	94	87	82	79	92	86	82	79	85	81	78	84	81	78	83	80	78	77																			
8	91	84	79	76	90	83	79	76	82	78	76	81	78	75	80	77	75	74																			
9	88	81	76	73	87	80	76	73	80	76	73	79	75	73	78	75	73	72																			
10	85	78	74	71	85	78	74	71	77	73	71	76	73	71	76	73	70	69																			

AVERAGE LUMINANCE (cd/sqm):

	0°	45°	90°
0°	1062453	1062453	1062453
5°	1031951	1030752	1032004
10°	893828	887525	893618
15°	583177	580047	577131
20°	289991	300865	289600
25°	146076	164724	143086
30°	58484	63725	50954
35°	27126	25977	21781
40°	11711	13010	11031
45°	8259	10251	8335
50°	2846	7466	3001
55°	1641	3096	1721
60°	1148	1362	1148
65°	743	743	743
70°	448	313	448
75°	0	207	0
80°	0	0	0
85°	0	0	0

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 22.5°

Vertical Angle: 45°

Luminance: 10251 cd/sqm



TEST NUMBER: P792794

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1MW

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1220.6	28.3
10°-20°	1965.7	45.5
20°-30°	849.4	19.7
30°-40°	193.6	4.5
40°-50°	66.5	1.5
50°-60°	16.2	0.4
60°-70°	4.2	0.1
70°-80°	0.5	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	4035.8	93.5
0°-40°	4229.4	98.0
0°-60°	4312.1	99.9
0°-90°	4316.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4316.7	100.0

CANDELA DISTRIBUTION:

	0°	22.5°	45°	67.5°	90°	Flux
0°	13880	13880	13880	13880	13880	
5°	13431	13418	13415	13443	13431	1222
15°	7359	7271	7320	7296	7283	1971
25°	1730	1795	1950	1749	1694	828
35°	290	296	278	276	233	197
45°	76	95	95	95	77	54
55°	12	13	23	14	13	12
65°	4	4	4	4	4	4
75°	0	0	1	0	0	1
85°	0	0	0	0	0	0
90°	0	0	0	0	0	



TEST NUMBER: P792794

CATALOG NUMBER: LER6D45BD010-EC6DR3040509035-6LBDP1MW

CANDELA DISTRIBUTION (FULL):

	0°	22.5°	45°	67.5°	90°
0°	13880.4	13880.4	13880.4	13880.4	13880.4
2.5°	13788.4	13778.9	13784.3	13791.1	13793.9
5°	13430.6	13417.7	13415.0	13442.9	13431.3
7.5°	12709.0	12690.6	12662.6	12726.0	12785.3
10°	11500.0	11479.6	11418.9	11448.9	11497.3
12.5°	9715.2	9649.1	9647.7	9743.1	9730.2
15°	7359.3	7270.7	7319.8	7295.9	7283.0
17.5°	4948.9	4914.8	4980.3	4960.5	4875.3
20°	3560.1	3568.9	3693.6	3630.9	3555.3
22.5°	2597.8	2629.8	2777.7	2616.2	2556.9
25°	1729.6	1795.0	1950.4	1749.4	1694.2
27.5°	1063.8	1093.8	1251.2	1050.2	1020.2
30°	661.7	646.7	721.0	618.8	576.5
32.5°	434.1	415.0	438.9	393.9	359.8
35°	290.3	296.4	278.0	276.0	233.1
37.5°	181.3	208.5	184.0	196.3	149.9
40°	117.2	151.3	130.2	143.8	110.4
42.5°	96.1	116.5	107.0	113.8	98.1
45°	76.3	94.7	94.7	94.7	77.0
47.5°	42.3	63.4	81.1	64.7	45.0
50°	23.9	32.0	62.7	33.4	25.2
52.5°	16.4	18.4	42.9	19.1	17.0
55°	12.3	12.9	23.2	13.6	12.9
57.5°	9.5	10.2	12.3	10.2	9.5
60°	7.5	7.5	8.9	8.2	7.5
62.5°	5.5	5.5	6.1	5.5	5.5
65°	4.1	4.1	4.1	4.1	4.1
67.5°	2.0	2.7	2.7	2.7	2.7
70°	2.0	1.4	1.4	1.4	2.0
72.5°	1.4	0.7	0.7	0.7	0.7
75°	0.0	0.0	0.7	0.0	0.0
77.5°	0.0	0.0	0.0	0.0	0.0
80°	0.0	0.0	0.0	0.0	0.0
82.5°	0.0	0.0	0.0	0.0	0.0
85°	0.0	0.0	0.0	0.0	0.0
87.5°	0.0	0.0	0.0	0.0	0.0
90°	0.0	0.0	0.0	0.0	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report





— 0°-180° - - 45°-225° - - - - 90°-270°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)