

Scaled data based on original data using  
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-  
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P793079

Luminaire Tested: LER6D45BD010-EC6DR6040509035-6LBDP1B

Issue Date: 2/5/2024

**Test Information**

Test Method: LM-79-2019  
Report Number: P793079  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-57)  
Test Lab: COOPER LIGHTING SOLUTIONS  
Issue Date: 2/5/2024  
Manufacturer: COOPER LIGHTING SOLUTIONS  
Product Line: PORTFOLIO  
Catalog Number: LER6D45BD010-EC6DR6040509035-6LBDP1B  
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR BLACK TRIM, WITH 60° OPTIC  
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3913.3 lumens  
Efficiency: N/A  
Efficacy: 101.1 lumens/watt  
Spacing Criteria (0/90/45): 0.91 / 0.91 / 0.83  
Luminous Opening: Circular (Dia: 0.35' x H: 0')  
CIE Type: Direct  
  
Input Watts (W): 38.7  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 24 FT




Downlight

TEST NUMBER: P793079

CATALOG NUMBER: LER6D45BD010-EC6DR6040509035-6LBDP1B

### Luminous Intensity Polar Plot





TEST NUMBER: P793079

CATALOG NUMBER: LER6D45BD010-EC6DR6040509035-6LBDP1B

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	113	110	108	105	111	108	106	104	104	102	100	100	99	97	97	96	95	93																			
2	107	102	98	95	105	101	97	94	97	94	92	94	92	90	92	90	88	86																			
3	102	96	90	86	100	94	89	86	91	88	84	89	86	83	87	84	82	80																			
4	97	89	84	80	95	88	83	79	86	82	78	84	80	77	82	79	76	75																			
5	92	84	78	74	91	83	78	74	81	77	73	80	76	72	78	75	72	70																			
6	88	79	73	69	87	78	73	69	77	72	68	75	71	68	74	70	67	66																			
7	84	75	69	65	83	74	68	64	73	68	64	72	67	64	71	67	63	62																			
8	80	71	65	61	79	70	65	61	69	64	60	68	64	60	67	63	60	59																			
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55																			
10	73	64	58	54	72	63	58	54	62	58	54	62	57	54	61	57	54	53																			

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	507789
5°	520280
10°	526562
15°	501620
20°	442279
25°	357726
30°	241969
35°	121258
40°	19669
45°	19253
50°	19633
55°	19925
60°	20475
65°	20941
70°	21436
75°	21699
80°	20953
85°	17425

**MAXIMUM LUMINANCE 45°-90°:**

Horizontal Angle: 0°  
 Vertical Angle: 75°  
 Luminance: 21699 cd/sqm



TEST NUMBER: P793079

CATALOG NUMBER: LER6D45BD010-EC6DR6040509035-6LBDP1B

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	453.4	11.6
10°-20°	1226.6	31.3
20°-30°	1319.8	33.7
30°-40°	573.7	14.7
40°-50°	96.4	2.5
50°-60°	93.7	2.4
60°-70°	80.1	2.0
70°-80°	53.6	1.4
80°-90°	16.0	0.4
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2999.8	76.7
0°-40°	3573.5	91.3
0°-60°	3763.5	96.2
0°-90°	3913.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3913.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	4648	
5°	4744	453
15°	4435	1227
25°	2967	1320
35°	909	574
45°	125	96
55°	105	94
65°	81	80
75°	51	54
85°	14	16
90°	0	



TEST NUMBER: P793079

CATALOG NUMBER: LER6D45BD010-EC6DR6040509035-6LBDP1B

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	4647.5
2.5°	4778.2
5°	4743.7
7.5°	4754.6
10°	4746.1
12.5°	4648.2
15°	4434.6
17.5°	4148.0
20°	3803.8
22.5°	3435.5
25°	2967.3
27.5°	2373.4
30°	1917.9
32.5°	1478.2
35°	909.1
37.5°	388.9
40°	137.9
42.5°	127.0
45°	124.6
47.5°	120.4
50°	115.5
52.5°	110.1
55°	104.6
57.5°	99.2
60°	93.7
62.5°	87.7
65°	81.0
67.5°	74.4
70°	67.1
72.5°	59.3
75°	51.4
77.5°	42.3
80°	33.3
82.5°	23.6
85°	13.9
87.5°	4.8
90°	0.0

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report





Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal  
Cooper Lighting Solutions Photometric Lab  
1121 Highway 74 South  
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)