

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269



Scaled data based on original data using
LM-79-2019 Approved Method: Electrical and Photometric Measurements of Solid-
State Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

Brand: PORTFOLIO

Report Number: P794063

Luminaire Tested: LER6D55D010-EC6DR6555659024-6LBDP1B

Issue Date: 2/5/2024

Test Information

Test Method: LM-79-2019
Report Number: P794063
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-2307-078-59)
Test Lab: COOPER LIGHTING SOLUTIONS
Issue Date: 2/5/2024
Manufacturer: COOPER LIGHTING SOLUTIONS
Product Line: PORTFOLIO
Catalog Number: LER6D55D010-EC6DR6555659024-6LBDP1B
Description: 6 INCH ROUND DEEP 45° CUTOFF SPECULAR BLACK TRIM, WITH 65° OPTIC
Light Source: (1) HIGH LUMEN LED 90CRI / 2400K CCT
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3641.6 lumens
Efficiency: N/A
Efficacy: 62.6 lumens/watt
Spacing Criteria (0/90/45): 0.98 / 0.98 / 0.92
Luminous Opening: Circular (Dia: 0.35' x H: 0')
CIE Type: Direct


Input Watts (W): 58.2
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 24 FT



Downlight

TEST NUMBER: P794063
CATALOG NUMBER: LER6D55D010-EC6DR6555659024-6LBDP1B

Luminous Intensity Polar Plot





TEST NUMBER: P794063

CATALOG NUMBER: LER6D55D010-EC6DR6555659024-6LBDP1B

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	111	108	106	111	108	106	104	104	103	101	101	99	98	97	96	95	93		
2	108	103	99	95	106	101	97	94	98	95	92	95	92	90	92	90	88	87		
3	102	96	91	87	100	94	90	86	92	88	85	89	86	83	87	84	82	80		
4	97	89	84	79	95	88	83	79	86	82	78	84	80	77	82	79	76	75		
5	92	83	78	73	90	83	77	73	81	76	72	79	75	72	77	74	71	69		
6	87	78	72	68	86	77	72	68	76	71	67	74	70	67	73	69	66	65		
7	83	73	67	63	81	73	67	63	71	66	62	70	66	62	69	65	62	60		
8	79	69	63	59	77	68	63	59	67	62	58	66	62	58	65	61	58	57		
9	75	65	59	55	74	65	59	55	64	58	55	63	58	55	62	58	54	53		
10	71	61	56	52	70	61	55	52	60	55	51	59	55	51	59	54	51	50		

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	391754
5°	392077
10°	405875
15°	406547
20°	374294
25°	318919
30°	244139
35°	172491
40°	101809
45°	41334
50°	14975
55°	8343
60°	4786
65°	2637
70°	2779
75°	2153
80°	2265
85°	1880

MAXIMUM LUMINANCE 45°-90°:

Horizontal Angle: 0°
 Vertical Angle: 45°
 Luminance: 41334 cd/sqm



TEST NUMBER: P794063

CATALOG NUMBER: LER6D55D010-EC6DR6555659024-6LBDP1B

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	345.2	9.5
10°-20°	995.9	27.3
20°-30°	1194.9	32.8
30°-40°	803.0	22.1
40°-50°	240.4	6.6
50°-60°	42.4	1.2
60°-70°	12.1	0.3
70°-80°	5.9	0.2
80°-90°	1.9	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2536.0	69.6
0°-40°	3339.0	91.7
0°-60°	3621.8	99.5
0°-90°	3641.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3641.6	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3586	
5°	3575	345
15°	3594	996
25°	2645	1195
35°	1293	803
45°	268	240
55°	44	42
65°	10	12
75°	5	6
85°	2	2
90°	0	



TEST NUMBER: P794063

CATALOG NUMBER: LER6D55D010-EC6DR6555659024-6LBDP1B

CANDELA DISTRIBUTION (FULL):

0°	
0°	3585.5
2.5°	3600.7
5°	3574.8
7.5°	3628.8
10°	3658.3
12.5°	3651.2
15°	3594.1
17.5°	3454.5
20°	3219.1
22.5°	2941.9
25°	2645.4
27.5°	2310.7
30°	1935.1
32.5°	1594.8
35°	1293.2
37.5°	995.1
40°	713.8
42.5°	466.2
45°	267.5
47.5°	141.6
50°	88.1
52.5°	61.1
55°	43.8
57.5°	31.6
60°	21.9
62.5°	14.3
65°	10.2
67.5°	9.2
70°	8.7
72.5°	6.6
75°	5.1
77.5°	4.6
80°	3.6
82.5°	2.5
85°	1.5
87.5°	1.0
90°	0.0

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Report Generated By 670245859 / DESKTOP-T8S5UU9

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



— 0°-180°

Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



Signify Classified - Internal
Cooper Lighting Solutions Photometric Lab
1121 Highway 74 South
Peachtree City, GA 30269

Scaled Data Report



(END OF REPORT)