

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P175422

Luminaire Tested: **LDA6A10940D010TE LARL20NF 6LFC1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P175422
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P26263)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA6A10940D010TE LARL20NF 6LFC1
Description: PORTFOLIO 6" Flat Cone, Self-flange Trim Ring, 20° Narrow Flood
Optic, at 0° tilt
Light Source: (1) HIGH LUMEN LED 90CRI / 4000K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 823.9 lumens
Efficiency: N/A
Efficacy: 59.5 lumens/watt
Spacing Criteria (0/90/45): 0.35 / 0.35 / 0.34
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct


Input Watts (W): 13.84
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P175422

CATALOG NUMBER: LDA6A10940D010TE LARL20NF 6LFC1

Luminous Intensity Polar Plot





TEST NUMBER: P175422

CATALOG NUMBER: LDA6A10940D010TE LARL20NF 6LFC1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20
RC	80				70				50				30				10
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50
RCR																	
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102
1	115	114	112	110	113	111	110	108	107	106	105		104	103	102		100
2	112	109	106	104	110	107	105	103	104	102	101		101	100	98		99
3	109	105	102	99	107	104	101	98	101	99	97		99	97	95		97
4	106	102	98	95	105	101	97	95	99	96	94		97	95	93		95
5	104	99	95	92	102	98	94	92	96	93	91		95	92	90		93
6	101	96	92	90	100	95	92	89	94	91	89		93	90	88		92
7	99	93	90	87	98	93	89	87	92	89	87		91	88	86		90
8	97	91	87	85	96	91	87	85	90	87	85		89	86	84		88
9	95	89	85	83	94	89	85	83	88	85	83		87	84	82		86
10	93	87	84	81	92	87	83	81	86	83	81		85	83	81		85

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	299071
5°	247270
10°	159015
15°	64824
20°	30943
25°	11595
30°	829
35°	161
40°	64
45°	23
50°	26
55°	0
60°	0
65°	0
70°	0
75°	0
80°	0
85°	0



TEST NUMBER: P175422

CATALOG NUMBER: LDA6A10940D010TE LARL20NF 6LFC1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	378.9	46.0
10°-20°	347.1	42.1
20°-30°	95.2	11.5
30°-40°	2.3	0.3
40°-50°	0.3	0.0
50°-60°	0.0	0.0
60°-70°	0.0	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	821.2	99.7
0°-40°	823.5	100.0
0°-60°	823.9	100.0
0°-90°	823.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	823.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5456	
5°	4493	379
15°	1142	347
25°	192	95
35°	2	2
45°	0	0
55°	0	0
65°	0	0
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P175422

CATALOG NUMBER: LDA6A10940D010TE LARL20NF 6LFC1

CANDELA DISTRIBUTION (FULL):

	0°
0°	5455.5
1°	5376.0
2°	5199.6
3°	4984.1
4°	4742.3
5°	4493.4
6°	4231.1
7°	3947.4
8°	3623.4
9°	3259.2
10°	2856.6
11°	2431.1
12°	2034.5
13°	1676.5
14°	1386.1
15°	1142.2
17.5°	731.9
20°	530.4
22.5°	358.6
25°	191.7
27.5°	64.2
30°	13.1
32.5°	4.6
35°	2.4
37.5°	1.5
40°	0.9
42.5°	0.6
45°	0.3
47.5°	0.3
50°	0.3
52.5°	0.0
55°	0.0
57.5°	0.0
60°	0.0
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0



TEST NUMBER: P175422

CATALOG NUMBER: LDA6A10940D010TE LARL20NF 6LFC1

CANDELA DISTRIBUTION (continued):

0°
90° | 0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







85°	0.0
87.5°	0.0



(END OF REPORT)