

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204762

Luminaire Tested: **LSR6B10D010BZ EC6B10209024 6LBCSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204762
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B10D010BZ EC6B10209024 6LBCSMW1
Description: PORTFOLIO 6IN CYLINDER
SHALLOW DISTRIBUTION WITH CAST MATTE WHITE TRIM
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W
DL3-11.1 W DLE-11.39 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 843.3 lumens
Efficiency: N/A
Efficacy: 85.2 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204762

CATALOG NUMBER: LSR6B10D010BZ EC6B10209024 6LBCSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204762

CATALOG NUMBER: LSR6B10D010BZ EC6B10209024 6LBCSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	110	106	102	99	108	104	100	97	100	97	94	96	93	91	92	90	89	87	87	87	87
2	101	94	87	82	99	92	86	81	88	84	79	85	81	78	82	79	76	74	74	74	74
3	93	83	75	70	90	81	74	69	79	73	68	76	71	67	73	69	65	63	63	63	63
4	85	74	66	60	83	73	65	59	70	64	58	68	62	58	66	61	57	55	55	55	55
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48	48	48	48
6	73	60	52	45	71	59	51	45	57	50	45	56	49	44	54	49	44	42	42	42	42
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	50	44	39	37	37	37	37
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	33	33	33	33
9	59	46	38	33	57	45	38	32	44	37	32	43	37	32	42	36	32	30	30	30	30
10	55	42	35	30	54	42	34	30	41	34	29	40	34	29	39	33	29	27	27	27	27

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204762

CATALOG NUMBER: LSR6B10D010BZ EC6B10209024 6LBCSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	32.6	3.9
10°-20°	92.9	11.0
20°-30°	139.8	16.6
30°-40°	165.6	19.6
40°-50°	164.8	19.5
50°-60°	132.9	15.8
60°-70°	80.4	9.5
70°-80°	29.8	3.5
80°-90°	4.4	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	265.3	31.5
0°-40°	431.0	51.1
0°-60°	728.6	86.4
0°-90°	843.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	843.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	344	
5°	343	33
15°	329	93
25°	304	140
35°	265	166
45°	215	165
55°	148	133
65°	81	80
75°	27	30
85°	4	4
90°	0	



TEST NUMBER: P204762

CATALOG NUMBER: LSR6B10D010BZ EC6B10209024 6LBCSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	344.4
2.5°	344.4
5°	342.9
7.5°	341.9
10°	338.8
12.5°	333.7
15°	329.1
17.5°	324.0
20°	317.9
22.5°	311.7
25°	303.6
27.5°	294.9
30°	285.2
32.5°	276.0
35°	265.2
37.5°	254.0
40°	240.7
42.5°	227.9
45°	214.6
47.5°	199.8
50°	183.5
52.5°	166.6
55°	148.2
57.5°	131.8
60°	113.4
62.5°	97.1
65°	80.7
67.5°	65.4
70°	51.1
72.5°	38.3
75°	27.1
77.5°	17.4
80°	10.2
82.5°	6.1
85°	3.6
87.5°	1.5
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)