

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203529

Luminaire Tested: **LSR6B10D010BZ EC6B10209727 6LBMMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203529
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B10D010BZ EC6B10209727 6LBMMW1
Description: PORTFOLIO 6IN CYLINDER
MEDIUM DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W
DL3-11.1 W DLE-11.39 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 608.8 lumens
Efficiency: N/A
Efficacy: 61.5 lumens/watt
Spacing Criteria (0/90/45): 1 / 1 / 0.97
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 9.9
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203529

CATALOG NUMBER: LSR6B10D010BZ EC6B10209727 6LBMMW1

Luminous Intensity Polar Plot





TEST NUMBER: P203529

CATALOG NUMBER: LSR6B10D010BZ EC6B10209727 6LBMMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	108	104	101	109	105	103	100	101	99	97	98	96	94	94	92	91	89		
2	104	97	92	88	101	96	91	87	92	88	85	89	86	83	86	83	81	79		
3	97	88	82	77	95	87	81	76	84	79	75	82	77	74	79	76	73	71		
4	90	81	74	68	88	80	73	68	77	72	67	75	70	66	73	69	65	64		
5	85	74	67	61	83	73	66	61	71	65	61	69	64	60	68	63	59	58		
6	79	68	61	56	78	68	61	56	66	60	55	64	59	55	63	58	54	53		
7	75	63	56	51	73	63	56	51	61	55	50	60	54	50	59	54	50	48		
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44		
9	66	55	48	43	65	54	48	43	53	47	43	52	47	43	51	46	43	41		
10	63	51	45	40	62	51	44	40	50	44	40	49	44	40	48	43	40	38		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203529

CATALOG NUMBER: LSR6B10D010BZ EC6B10209727 6LBMMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	42.0	6.9
10°-20°	112.4	18.5
20°-30°	150.9	24.8
30°-40°	123.8	20.3
40°-50°	74.3	12.2
50°-60°	49.4	8.1
60°-70°	33.1	5.4
70°-80°	17.8	2.9
80°-90°	5.0	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	305.3	50.1
0°-40°	429.1	70.5
0°-60°	552.8	90.8
0°-90°	608.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	608.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	454	
5°	447	42
15°	400	112
25°	332	151
35°	196	124
45°	94	74
55°	55	49
65°	34	33
75°	17	18
85°	4	5
90°	0	



TEST NUMBER: P203529

CATALOG NUMBER: LSR6B10D010BZ EC6B10209727 6LBMMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	454.2
2.5°	450.9
5°	446.7
7.5°	437.4
10°	426.5
12.5°	413.1
15°	400.5
17.5°	385.4
20°	370.3
22.5°	353.5
25°	332.5
27.5°	307.3
30°	273.7
32.5°	235.9
35°	196.5
37.5°	162.9
40°	134.3
42.5°	111.7
45°	94.0
47.5°	79.8
50°	69.7
52.5°	61.3
55°	54.6
57.5°	48.7
60°	43.7
62.5°	37.8
65°	33.6
67.5°	28.5
70°	24.3
72.5°	20.2
75°	16.8
77.5°	13.4
80°	10.1
82.5°	7.6
85°	4.2
87.5°	1.7
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)