

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203316

Luminaire Tested: **LSR6B10D010BZ EC6B10208040 6LBMWH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P203316  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR6B10D010BZ EC6B10208040 6LBMWH1  
Description: PORTFOLIO 6IN CYLINDER  
MEDIUM DISTRIBUTION WITH WHEAT TRIM  
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W  
DL3-11.1 W DLE-11.39 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 869.3 lumens  
Efficiency: N/A  
Efficacy: 87.8 lumens/watt  
Spacing Criteria (0/90/45): 0.83 / 0.83 / 0.85  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 9.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P203316

CATALOG NUMBER: LSR6B10D010BZ EC6B10208040 6LBMWH1

### Luminous Intensity Polar Plot





TEST NUMBER: P203316

CATALOG NUMBER: LSR6B10D010BZ EC6B10208040 6LBMWH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	114	111	108	106	111	109	106	104	105	103	101	101	100	98	97	96	95	94																			
2	108	103	99	96	106	101	98	95	98	95	93	95	93	91	93	91	89	87																			
3	103	96	91	87	101	95	90	87	92	88	85	90	87	84	88	85	83	81																			
4	97	90	85	80	96	89	84	80	87	82	79	85	81	78	83	80	77	76																			
5	93	84	79	74	91	83	78	74	82	77	73	80	76	73	78	75	72	71																			
6	88	79	73	69	87	78	73	69	77	72	68	76	71	68	74	70	67	66																			
7	84	75	69	64	82	74	68	64	73	68	64	71	67	64	70	66	63	62																			
8	80	70	64	60	78	70	64	60	69	64	60	68	63	60	67	62	59	58																			
9	76	66	61	57	75	66	60	57	65	60	56	64	59	56	63	59	56	55																			
10	72	63	57	53	71	62	57	53	62	57	53	61	56	53	60	56	53	52																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P203316

CATALOG NUMBER: LSR6B10D010BZ EC6B10208040 6LBMWH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	99.1	11.4
10°-20°	243.4	28.0
20°-30°	281.6	32.4
30°-40°	180.0	20.7
40°-50°	51.0	5.9
50°-60°	9.1	1.1
60°-70°	3.7	0.4
70°-80°	1.3	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	624.1	71.8
0°-40°	804.1	92.5
0°-60°	864.3	99.4
0°-90°	869.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	869.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1084	
5°	1065	99
15°	873	243
25°	621	282
35°	284	180
45°	59	51
55°	8	9
65°	4	4
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P203316

CATALOG NUMBER: LSR6B10D010BZ EC6B10208040 6LBMWH1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1084.4
2.5°	1083.2
5°	1065.1
7.5°	1032.4
10°	986.5
12.5°	933.3
15°	872.9
17.5°	810.0
20°	748.3
22.5°	687.9
25°	621.4
27.5°	548.9
30°	467.9
32.5°	377.2
35°	284.1
37.5°	205.5
40°	142.7
42.5°	94.3
45°	59.2
47.5°	35.1
50°	20.6
52.5°	12.1
55°	8.5
57.5°	7.3
60°	6.0
62.5°	4.8
65°	3.6
67.5°	2.4
70°	2.4
72.5°	1.2
75°	1.2
77.5°	1.2
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)