

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P202708

Luminaire Tested: **LSR6B15D010BZ EC6B10208030 6LBWH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P202708  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR6B15D010BZ EC6B10208030 6LBWH1  
Description: PORTFOLIO 6IN CYLINDER  
WIDE DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM  
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W  
DL3-15.28 W DLE-15.432 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1296.7 lumens  
Efficiency: N/A  
Efficacy: 90.7 lumens/watt  
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.16  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 14.3  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P202708

CATALOG NUMBER: LSR6B15D010BZ EC6B10208030 6LBWH1

### Luminous Intensity Polar Plot





TEST NUMBER: P202708

CATALOG NUMBER: LSR6B15D010BZ EC6B10208030 6LBWH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	112	109	106	103	110	107	104	101	103	100	98	99	97	95	95	94	93	91																			
2	105	99	94	90	103	97	93	89	94	90	87	91	88	85	88	85	83	81																			
3	98	90	84	79	96	89	83	78	86	81	77	83	79	76	81	78	75	73																			
4	92	82	75	70	90	81	75	70	79	73	69	77	72	68	75	71	67	65																			
5	86	75	68	63	84	74	68	63	72	66	62	71	65	61	69	64	61	59																			
6	80	69	62	57	78	68	61	56	67	61	56	65	60	56	64	59	55	53																			
7	75	64	56	51	73	63	56	51	62	55	51	60	55	51	59	54	50	49																			
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44																			
9	66	55	48	43	65	54	47	43	53	47	43	52	47	42	51	46	42	41																			
10	62	51	44	40	61	50	44	39	50	43	39	49	43	39	48	43	39	38																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P202708

CATALOG NUMBER: LSR6B15D010BZ EC6B10208030 6LBWH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	75.5	5.8
10°-20°	214.3	16.5
20°-30°	314.3	24.2
30°-40°	327.1	25.2
40°-50°	226.3	17.5
50°-60°	98.5	7.6
60°-70°	30.2	2.3
70°-80°	9.1	0.7
80°-90°	1.4	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	604.1	46.6
0°-40°	931.2	71.8
0°-60°	1256.1	96.9
0°-90°	1296.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1296.7	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	800	
5°	796	76
15°	761	214
25°	687	314
35°	529	327
45°	292	226
55°	106	99
65°	29	30
75°	8	9
85°	2	1
90°	0	



TEST NUMBER: P202708

CATALOG NUMBER: LSR6B15D010BZ EC6B10208030 6LBWH1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	799.8
2.5°	801.5
5°	796.4
7.5°	789.7
10°	781.3
12.5°	772.9
15°	761.1
17.5°	746.0
20°	729.2
22.5°	710.7
25°	687.2
27.5°	657.0
30°	618.3
32.5°	578.0
35°	529.3
37.5°	475.5
40°	413.3
42.5°	351.2
45°	292.4
47.5°	236.9
50°	188.2
52.5°	142.8
55°	105.9
57.5°	75.6
60°	52.1
62.5°	38.6
65°	28.6
67.5°	21.8
70°	15.1
72.5°	11.8
75°	8.4
77.5°	5.0
80°	3.4
82.5°	1.7
85°	1.7
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)