

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203127

Luminaire Tested: **LSR6B15D010BZ EC6B10209035 6LBWMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203127
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B15D010BZ EC6B10209035 6LBWMW1
Description: PORTFOLIO 6IN CYLINDER
WIDE DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1200.4 lumens
Efficiency: N/A
Efficacy: 83.9 lumens/watt
Spacing Criteria (0/90/45): 1.13 / 1.13 / 1.15
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203127

CATALOG NUMBER: LSR6B15D010BZ EC6B10209035 6LBWMW1

Luminous Intensity Polar Plot





TEST NUMBER: P203127

CATALOG NUMBER: LSR6B15D010BZ EC6B10209035 6LBWMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | 100 | 100 | 100 |
| 1 | 111 | 107 | 104 | 100 | 108 | 105 | 102 | 99 | 101 | 98 | 96 | 97 | 95 | 93 | 93 | 92 | 90 | 88 | 88 | 88 | 88 |
| 2 | 103 | 96 | 90 | 86 | 100 | 94 | 89 | 85 | 91 | 86 | 83 | 88 | 84 | 81 | 85 | 82 | 79 | 77 | 77 | 77 | 77 |
| 3 | 95 | 86 | 80 | 74 | 93 | 85 | 79 | 74 | 82 | 77 | 72 | 80 | 75 | 71 | 77 | 73 | 70 | 68 | 68 | 68 | 68 |
| 4 | 89 | 78 | 71 | 65 | 86 | 77 | 70 | 65 | 75 | 69 | 64 | 72 | 67 | 63 | 70 | 66 | 62 | 60 | 60 | 60 | 60 |
| 5 | 82 | 71 | 64 | 58 | 80 | 70 | 63 | 58 | 68 | 62 | 57 | 66 | 61 | 56 | 65 | 60 | 56 | 54 | 54 | 54 | 54 |
| 6 | 77 | 65 | 57 | 52 | 75 | 64 | 57 | 52 | 63 | 56 | 51 | 61 | 55 | 51 | 60 | 54 | 50 | 49 | 49 | 49 | 49 |
| 7 | 72 | 60 | 52 | 47 | 70 | 59 | 52 | 47 | 58 | 51 | 46 | 56 | 50 | 46 | 55 | 50 | 46 | 44 | 44 | 44 | 44 |
| 8 | 67 | 55 | 48 | 42 | 66 | 55 | 47 | 42 | 53 | 47 | 42 | 52 | 46 | 42 | 51 | 46 | 42 | 40 | 40 | 40 | 40 |
| 9 | 63 | 51 | 44 | 39 | 62 | 51 | 44 | 39 | 50 | 43 | 39 | 49 | 43 | 38 | 48 | 42 | 38 | 37 | 37 | 37 | 37 |
| 10 | 60 | 48 | 40 | 36 | 58 | 47 | 40 | 36 | 46 | 40 | 36 | 45 | 40 | 35 | 45 | 39 | 35 | 34 | 34 | 34 | 34 |

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203127

CATALOG NUMBER: LSR6B15D010BZ EC6B10209035 6LBWMW1

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 63.5 | 5.3 |
| 10°-20° | 178.0 | 14.8 |
| 20°-30° | 256.5 | 21.4 |
| 30°-40° | 266.3 | 22.2 |
| 40°-50° | 196.9 | 16.4 |
| 50°-60° | 117.6 | 9.8 |
| 60°-70° | 71.5 | 6.0 |
| 70°-80° | 39.1 | 3.3 |
| 80°-90° | 10.9 | 0.9 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 498.1 | 41.5 |
| 0°-40° | 764.4 | 63.7 |
| 0°-60° | 1079.0 | 89.9 |
| 0°-90° | 1200.4 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 1200.4 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|-----|------|
| 0° | 674 | |
| 5° | 670 | 63 |
| 15° | 632 | 178 |
| 25° | 559 | 257 |
| 35° | 430 | 266 |
| 45° | 253 | 197 |
| 55° | 128 | 118 |
| 65° | 71 | 71 |
| 75° | 36 | 39 |
| 85° | 9 | 11 |
| 90° | 0 | |



TEST NUMBER: P203127

CATALOG NUMBER: LSR6B15D010BZ EC6B10209035 6LBWMW1

CANDELA DISTRIBUTION (FULL):

| | 0° |
|-------|-------|
| 0° | 674.2 |
| 2.5° | 674.2 |
| 5° | 669.8 |
| 7.5° | 664.0 |
| 10° | 655.2 |
| 12.5° | 645.0 |
| 15° | 631.9 |
| 17.5° | 617.4 |
| 20° | 602.8 |
| 22.5° | 582.4 |
| 25° | 559.1 |
| 27.5° | 534.4 |
| 30° | 502.3 |
| 32.5° | 470.3 |
| 35° | 429.5 |
| 37.5° | 387.3 |
| 40° | 340.7 |
| 42.5° | 295.6 |
| 45° | 253.4 |
| 47.5° | 215.5 |
| 50° | 182.0 |
| 52.5° | 152.9 |
| 55° | 128.1 |
| 57.5° | 109.2 |
| 60° | 93.2 |
| 62.5° | 81.5 |
| 65° | 71.3 |
| 67.5° | 62.6 |
| 70° | 53.9 |
| 72.5° | 45.1 |
| 75° | 36.4 |
| 77.5° | 29.1 |
| 80° | 21.8 |
| 82.5° | 16.0 |
| 85° | 8.7 |
| 87.5° | 4.4 |
| 90° | 0.0 |



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)