

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203534

Luminaire Tested: **LSR6B15D010BZ EC6B10208040 6LBMMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203534
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B15D010BZ EC6B10208040 6LBMMW1
Description: PORTFOLIO 6IN CYLINDER
MEDIUM DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1218.1 lumens
Efficiency: N/A
Efficacy: 85.2 lumens/watt
Spacing Criteria (0/90/45): 1 / 1 / 0.97
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203534

CATALOG NUMBER: LSR6B15D010BZ EC6B10208040 6LBMMW1

Luminous Intensity Polar Plot





TEST NUMBER: P203534

CATALOG NUMBER: LSR6B15D010BZ EC6B10208040 6LBMMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	108	104	101	109	105	103	100	101	99	97	98	96	94	94	92	91	89		
2	104	97	92	88	101	96	91	87	92	88	85	89	86	83	86	83	81	79		
3	97	88	82	77	95	87	81	76	84	79	75	82	77	74	79	76	73	71		
4	90	81	74	68	88	80	73	68	77	72	67	75	70	66	73	69	65	64		
5	85	74	67	61	83	73	66	61	71	65	61	69	64	60	68	63	59	58		
6	79	68	61	56	78	68	61	56	66	60	55	64	59	55	63	58	54	53		
7	75	63	56	51	73	63	56	51	61	55	50	60	54	50	59	54	50	48		
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44		
9	66	55	48	43	65	54	48	43	53	47	43	52	47	43	51	46	43	41		
10	63	51	45	40	62	51	44	40	50	44	40	49	44	40	48	43	40	38		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203534

CATALOG NUMBER: LSR6B15D010BZ EC6B10208040 6LBMMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	84.0	6.9
10°-20°	224.9	18.5
20°-30°	302.0	24.8
30°-40°	247.7	20.3
40°-50°	148.7	12.2
50°-60°	98.8	8.1
60°-70°	66.3	5.4
70°-80°	35.7	2.9
80°-90°	10.1	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	610.8	50.1
0°-40°	858.5	70.5
0°-60°	1106.1	90.8
0°-90°	1218.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1218.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	909	
5°	894	84
15°	801	225
25°	665	302
35°	393	248
45°	188	149
55°	109	99
65°	67	66
75°	34	36
85°	8	10
90°	0	



TEST NUMBER: P203534

CATALOG NUMBER: LSR6B15D010BZ EC6B10208040 6LBMMW1

CANDELA DISTRIBUTION (FULL):

0°	
0°	908.9
2.5°	902.2
5°	893.8
7.5°	875.3
10°	853.4
12.5°	826.6
15°	801.4
17.5°	771.1
20°	740.9
22.5°	707.3
25°	665.3
27.5°	614.9
30°	547.7
32.5°	472.1
35°	393.1
37.5°	325.9
40°	268.8
42.5°	223.4
45°	188.2
47.5°	159.6
50°	139.4
52.5°	122.6
55°	109.2
57.5°	97.4
60°	87.4
62.5°	75.6
65°	67.2
67.5°	57.1
70°	48.7
72.5°	40.3
75°	33.6
77.5°	26.9
80°	20.2
82.5°	15.1
85°	8.4
87.5°	3.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)