

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203129

Luminaire Tested: **LSR6B15D010BZ EC6B10209050 6LBWMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203129
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B15D010BZ EC6B10209050 6LBWMW1
Description: PORTFOLIO 6IN CYLINDER
WIDE DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-14.39 W DE010-14.29 W D5LT-14.34 W DMX-14.46 W DL2-15.8 W
DL3-15.28 W DLE-15.432 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1207.3 lumens
Efficiency: N/A
Efficacy: 84.4 lumens/watt
Spacing Criteria (0/90/45): 1.13 / 1.13 / 1.15
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.3
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203129

CATALOG NUMBER: LSR6B15D010BZ EC6B10209050 6LBWMW1

Luminous Intensity Polar Plot





TEST NUMBER: P203129

CATALOG NUMBER: LSR6B15D010BZ EC6B10209050 6LBWMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	111	107	104	100	108	105	102	99	101	98	96	97	95	93	93	92	90	88		
2	103	96	90	86	100	94	89	85	91	86	83	88	84	81	85	82	79	77		
3	95	86	80	74	93	85	79	74	82	77	72	80	75	71	77	73	70	68		
4	89	78	71	65	86	77	70	65	75	69	64	72	67	63	70	66	62	60		
5	82	71	64	58	80	70	63	58	68	62	57	66	61	56	65	60	56	54		
6	77	65	57	52	75	64	57	52	63	56	51	61	55	51	60	54	50	49		
7	72	60	52	47	70	59	52	47	58	51	46	56	50	46	55	50	46	44		
8	67	55	48	42	66	55	47	42	53	47	42	52	46	42	51	46	42	40		
9	63	51	44	39	62	51	44	39	50	43	39	49	43	38	48	42	38	37		
10	60	48	40	36	58	47	40	36	46	40	36	45	39	35	45	39	35	34		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203129

CATALOG NUMBER: LSR6B15D010BZ EC6B10209050 6LBWMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	63.8	5.3
10°-20°	179.1	14.8
20°-30°	258.0	21.4
30°-40°	267.9	22.2
40°-50°	198.0	16.4
50°-60°	118.3	9.8
60°-70°	71.9	6.0
70°-80°	39.4	3.3
80°-90°	11.0	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	500.9	41.5
0°-40°	768.8	63.7
0°-60°	1085.1	89.9
0°-90°	1207.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1207.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	678	
5°	674	64
15°	636	179
25°	562	258
35°	432	268
45°	255	198
55°	129	118
65°	72	72
75°	37	39
85°	9	11
90°	0	



TEST NUMBER: P203129

CATALOG NUMBER: LSR6B15D010BZ EC6B10209050 6LBWMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	678.0
2.5°	678.0
5°	673.6
7.5°	667.7
10°	658.9
12.5°	648.7
15°	635.5
17.5°	620.9
20°	606.2
22.5°	585.7
25°	562.3
27.5°	537.4
30°	505.2
32.5°	473.0
35°	432.0
37.5°	389.5
40°	342.6
42.5°	297.3
45°	254.8
47.5°	216.7
50°	183.0
52.5°	153.8
55°	128.9
57.5°	109.8
60°	93.7
62.5°	82.0
65°	71.8
67.5°	63.0
70°	54.2
72.5°	45.4
75°	36.6
77.5°	29.3
80°	22.0
82.5°	16.1
85°	8.8
87.5°	4.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)