

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P204783

Luminaire Tested: **LSR6B20D010BZ EC6B10208030 6LBCSMW1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P204783  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR6B20D010BZ EC6B10208030 6LBCSMW1  
Description: PORTFOLIO 6IN CYLINDER  
SHALLOW DISTRIBUTION WITH CAST MATTE WHITE TRIM  
WATTAGE D010TR-21.86 W DE010-20.46 W D5LT-21.24 W DMX-20.89 W DL2-22.5 W  
DL3-21.8 6 W DLE-22.46 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2238.5 lumens  
Efficiency: N/A  
Efficacy: 107.6 lumens/watt  
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 20.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P204783

CATALOG NUMBER: LSR6B20D010BZ EC6B10208030 6LBCSMW1

### Luminous Intensity Polar Plot





TEST NUMBER: P204783

CATALOG NUMBER: LSR6B20D010BZ EC6B10208030 6LBCSMW1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	110	106	102	99	108	104	100	97	100	97	94	96	93	91	92	90	89	87																			
2	101	94	87	82	99	92	86	81	88	84	79	85	81	78	82	79	76	74																			
3	93	83	75	70	90	81	74	69	79	73	68	76	71	67	73	69	65	63																			
4	85	74	66	60	83	73	65	59	70	64	58	68	62	58	66	61	57	55																			
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48																			
6	73	60	52	45	71	59	51	45	57	50	45	56	49	44	54	49	44	42																			
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	50	44	39	37																			
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	33																			
9	59	46	38	33	57	45	38	32	44	37	32	43	37	32	42	36	32	30																			
10	55	42	35	30	54	42	34	30	41	34	29	40	34	29	39	33	29	27																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P204783

CATALOG NUMBER: LSR6B20D010BZ EC6B10208030 6LBCSMW1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	86.6	3.9
10°-20°	246.6	11.0
20°-30°	371.0	16.6
30°-40°	439.7	19.6
40°-50°	437.5	19.5
50°-60°	352.7	15.8
60°-70°	213.3	9.5
70°-80°	79.2	3.5
80°-90°	11.8	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	704.2	31.5
0°-40°	1143.9	51.1
0°-60°	1934.1	86.4
0°-90°	2238.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2238.5	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	914	
5°	910	87
15°	874	247
25°	806	371
35°	704	440
45°	570	438
55°	393	353
65°	214	213
75°	72	79
85°	10	12
90°	0	



TEST NUMBER: P204783

CATALOG NUMBER: LSR6B20D010BZ EC6B10208030 6LBCSMW1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	914.3
2.5°	914.3
5°	910.2
7.5°	907.5
10°	899.4
12.5°	885.8
15°	873.6
17.5°	860.0
20°	843.7
22.5°	827.5
25°	805.8
27.5°	782.7
30°	756.9
32.5°	732.5
35°	704.0
37.5°	674.2
40°	638.9
42.5°	605.0
45°	569.7
47.5°	530.4
50°	487.0
52.5°	442.2
55°	393.4
57.5°	350.0
60°	301.1
62.5°	257.7
65°	214.3
67.5°	173.6
70°	135.6
72.5°	101.7
75°	71.9
77.5°	46.1
80°	27.1
82.5°	16.3
85°	9.5
87.5°	4.1
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)