

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P202827

Luminaire Tested: **LSR6B20D010BZ EC6B10208050 6LBWWH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202827
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B20D010BZ EC6B10208050 6LBWWH1
Description: PORTFOLIO 6IN CYLINDER
WIDE DISTRIBUTION WITH WHEAT TRIM
WATTAGE D010TR-21.86 W DE010-20.46 W D5LT-21.24 W DMX-20.89 W DL2-22.5 W
DL3-21.8 6 W DLE-22.46 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1929.2 lumens
Efficiency: N/A
Efficacy: 92.7 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.18
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 20.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202827

CATALOG NUMBER: LSR6B20D010BZ EC6B10208050 6LBWWH1

Luminous Intensity Polar Plot





TEST NUMBER: P202827

CATALOG NUMBER: LSR6B20D010BZ EC6B10208050 6LBWWH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	113	109	107	104	110	107	105	102	103	101	99	99	98	96	96	95	93	92			
2	106	100	96	92	104	98	94	91	95	92	89	92	89	87	89	87	85	83			
3	99	92	86	81	97	90	85	81	88	83	79	85	81	78	83	80	77	75			
4	93	84	78	73	91	83	77	72	81	76	71	79	74	71	77	73	70	68			
5	87	77	71	66	85	76	70	65	75	69	65	73	68	64	71	67	63	62			
6	82	71	64	59	80	71	64	59	69	63	59	67	62	58	66	61	58	56			
7	77	66	59	54	75	65	59	54	64	58	54	63	57	53	61	57	53	51			
8	72	61	54	49	71	61	54	49	59	53	49	58	53	49	57	52	49	47			
9	68	57	50	45	67	56	50	45	55	49	45	54	49	45	53	48	45	43			
10	64	53	46	42	63	53	46	42	52	46	42	51	45	42	50	45	41	40			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202827

CATALOG NUMBER: LSR6B20D010BZ EC6B10208050 6LBWWH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	115.2	6.0
10°-20°	342.5	17.8
20°-30°	515.6	26.7
30°-40°	527.2	27.3
40°-50°	320.1	16.6
50°-60°	90.1	4.7
60°-70°	13.7	0.7
70°-80°	4.4	0.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	973.3	50.5
0°-40°	1500.4	77.8
0°-60°	1910.7	99.0
0°-90°	1929.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1929.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1198	
5°	1203	115
15°	1213	343
25°	1126	516
35°	854	527
45°	412	320
55°	90	90
65°	12	14
75°	5	4
85°	0	0
90°	0	



TEST NUMBER: P202827

CATALOG NUMBER: LSR6B20D010BZ EC6B10208050 6LBWWH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1198.3
2.5°	1198.3
5°	1203.1
7.5°	1210.4
10°	1210.4
12.5°	1215.2
15°	1212.8
17.5°	1208.0
20°	1191.0
22.5°	1166.8
25°	1125.7
27.5°	1079.7
30°	1016.7
32.5°	941.7
35°	854.5
37.5°	757.7
40°	646.3
42.5°	530.1
45°	411.5
47.5°	305.0
50°	215.4
52.5°	145.2
55°	89.6
57.5°	53.3
60°	26.6
62.5°	16.9
65°	12.1
67.5°	9.7
70°	7.3
72.5°	4.8
75°	4.8
77.5°	2.4
80°	2.4
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)