

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203249

Luminaire Tested: **LSR6B30D010BZ EC6B30508030 6LBMH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203249
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B30D010BZ EC6B30508030 6LBMH1
Description: PORTFOLIO 6IN CYLINDER
MEDIUM DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W
DL3-29.67 W DLE-29.73 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2160.0 lumens
Efficiency: N/A
Efficacy: 77.1 lumens/watt
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.93
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203249

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBMH1

Luminous Intensity Polar Plot





TEST NUMBER: P203249

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBMH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20					20					20					20					20					
RC	80					70					50					30					10					0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0		
RCR																										
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100					100			
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	92					92			
2	107	102	97	93	105	100	96	92	97	93	90	94	91	88	91	89	87	85					85			
3	101	94	88	84	99	92	87	84	90	86	82	87	84	81	85	82	80	78					78			
4	95	87	81	76	93	86	80	76	84	79	75	82	78	74	80	76	73	72					72			
5	90	81	75	70	88	80	74	70	78	73	69	76	72	68	75	71	68	66					66			
6	85	75	69	64	83	75	69	64	73	68	64	72	67	63	70	66	63	61					61			
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57					57			
8	76	66	60	55	75	65	59	55	64	59	55	63	58	55	62	58	54	53					53			
9	72	62	56	51	71	61	55	51	60	55	51	60	55	51	59	54	51	49					49			
10	69	58	52	48	68	58	52	48	57	52	48	56	51	48	55	51	48	46					46			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203249

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBMH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	195.4	9.0
10°-20°	505.6	23.4
20°-30°	655.1	30.3
30°-40°	486.4	22.5
40°-50°	205.3	9.5
50°-60°	72.9	3.4
60°-70°	28.1	1.3
70°-80°	9.8	0.5
80°-90°	1.3	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1356.2	62.8
0°-40°	1842.6	85.3
0°-60°	2120.9	98.2
0°-90°	2160.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2160.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2138	
5°	2091	195
15°	1804	506
25°	1453	655
35°	771	486
45°	253	205
55°	77	73
65°	28	28
75°	9	10
85°	0	1
90°	0	



TEST NUMBER: P203249

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBMH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2137.6
2.5°	2131.4
5°	2091.3
7.5°	2032.7
10°	1961.8
12.5°	1884.6
15°	1804.4
17.5°	1715.0
20°	1634.8
22.5°	1551.5
25°	1452.8
27.5°	1317.1
30°	1156.7
32.5°	968.5
35°	771.1
37.5°	604.6
40°	459.6
42.5°	342.4
45°	252.9
47.5°	185.1
50°	135.7
52.5°	101.8
55°	77.1
57.5°	58.6
60°	46.3
62.5°	33.9
65°	27.8
67.5°	21.6
70°	15.4
72.5°	12.3
75°	9.3
77.5°	6.2
80°	3.1
82.5°	3.1
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)