

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203043

Luminaire Tested: **LSR6B30D010BZ EC6B30508030 6LBWB1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P203043  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR6B30D010BZ EC6B30508030 6LBWB1  
Description: PORTFOLIO 6IN CYLINDER  
WIDE DISTRIBUTION WITH SPECULAR BLACK TRIM  
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W  
DL3-29.67 W DLE-29.73 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1662.3 lumens  
Efficiency: N/A  
Efficacy: 59.4 lumens/watt  
Spacing Criteria (0/90/45): 1.08 / 1.08 / 1.08  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 28  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P203043

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBWB1

### Luminous Intensity Polar Plot





TEST NUMBER: P203043

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBWB1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100																
1	113	110	107	105	110	108	105	103	104	102	100	100	98	97	96	95	94	92			92																
2	106	101	97	93	104	99	95	92	96	93	90	93	90	88	90	88	86	84			84																
3	100	93	87	83	98	92	86	82	89	85	81	86	83	80	84	81	78	77			77																
4	94	86	79	75	92	85	79	74	82	77	73	80	76	73	78	75	72	70			70																
5	89	79	73	68	87	78	72	67	76	71	67	75	70	66	73	69	66	64			64																
6	83	73	67	62	82	72	66	61	71	65	61	69	64	61	68	64	60	59			59																
7	78	68	61	56	77	67	61	56	66	60	56	65	60	56	63	59	55	54			54																
8	74	63	57	52	73	63	56	52	61	56	52	60	55	51	59	55	51	50			50																
9	70	59	52	48	69	58	52	48	57	52	48	57	51	47	56	51	47	46			46																
10	66	55	49	44	65	55	49	44	54	48	44	53	48	44	52	47	44	42			42																

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P203043

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBWB1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	117.8	7.1
10°-20°	329.4	19.8
20°-30°	461.4	27.8
30°-40°	440.6	26.5
40°-50°	251.0	15.1
50°-60°	61.3	3.7
60°-70°	0.8	0.0
70°-80°	0.0	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	908.6	54.7
0°-40°	1349.2	81.2
0°-60°	1661.5	100.0
0°-90°	1662.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1662.3	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1253	
5°	1243	118
15°	1168	329
25°	1009	461
35°	718	441
45°	322	251
55°	61	61
65°	0	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P203043

CATALOG NUMBER: LSR6B30D010BZ EC6B30508030 6LBWB1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	1252.8
2.5°	1252.8
5°	1242.7
7.5°	1229.1
10°	1219.0
12.5°	1198.7
15°	1168.2
17.5°	1141.1
20°	1107.2
22.5°	1063.2
25°	1009.0
27.5°	948.1
30°	880.4
32.5°	799.1
35°	717.8
37.5°	619.6
40°	514.7
42.5°	416.5
45°	321.7
47.5°	237.0
50°	165.9
52.5°	105.0
55°	60.9
57.5°	27.1
60°	6.8
62.5°	0.0
65°	0.0
67.5°	0.0
70°	0.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)