

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P203262

Luminaire Tested: **LSR6B40D010BZ EC6B30508030 6LBMH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P203262  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: io LED  
Catalog Number: LSR6B40D010BZ EC6B30508030 6LBMH1  
Description: PORTFOLIO 6IN CYLINDER  
MEDIUM DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM  
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57  
W DL3-44.71 W DLE-39.33 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 3053.7 lumens  
Efficiency: N/A  
Efficacy: 73.1 lumens/watt  
Spacing Criteria (0/90/45): 0.94 / 0.94 / 0.93  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P203262

CATALOG NUMBER: LSR6B40D010BZ EC6B30508030 6LBMH1

### Luminous Intensity Polar Plot





TEST NUMBER: P203262

CATALOG NUMBER: LSR6B40D010BZ EC6B30508030 6LBMH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	113	110	107	105	111	108	105	103	104	102	100	100	99	97	97	95	94	92			92
2	107	102	97	93	105	100	96	92	97	93	90	94	91	88	91	89	87	85			85
3	101	94	88	84	99	92	87	84	90	86	82	87	84	81	85	82	80	78			78
4	95	87	81	76	93	86	80	76	84	79	75	82	78	74	80	76	73	72			72
5	90	81	75	70	88	80	74	70	78	73	69	76	72	68	75	71	68	66			66
6	85	75	69	64	83	75	69	64	73	68	64	72	67	63	70	66	63	61			61
7	80	70	64	59	79	70	64	59	68	63	59	67	62	59	66	62	58	57			57
8	76	66	60	55	75	65	59	55	64	59	55	63	58	55	62	58	54	53			53
9	72	62	56	51	71	61	55	51	60	55	51	60	55	51	59	54	51	49			49
10	69	58	52	48	68	58	52	48	57	52	48	56	51	48	55	51	48	46			46

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P203262

CATALOG NUMBER: LSR6B40D010BZ EC6B30508030 6LBMH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	276.3	9.0
10°-20°	714.8	23.4
20°-30°	926.2	30.3
30°-40°	687.6	22.5
40°-50°	290.3	9.5
50°-60°	103.1	3.4
60°-70°	39.8	1.3
70°-80°	13.8	0.5
80°-90°	1.8	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1917.3	62.8
0°-40°	2605.0	85.3
0°-60°	2998.3	98.2
0°-90°	3053.7	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3053.7	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3022	
5°	2957	276
15°	2551	715
25°	2054	926
35°	1090	688
45°	358	290
55°	109	103
65°	39	40
75°	13	14
85°	0	2
90°	0	



TEST NUMBER: P203262

CATALOG NUMBER: LSR6B40D010BZ EC6B30508030 6LBMH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	3022.0
2.5°	3013.3
5°	2956.6
7.5°	2873.7
10°	2773.4
12.5°	2664.4
15°	2551.0
17.5°	2424.6
20°	2311.2
22.5°	2193.4
25°	2053.9
27.5°	1862.0
30°	1635.3
32.5°	1369.3
35°	1090.2
37.5°	854.7
40°	649.7
42.5°	484.0
45°	357.6
47.5°	261.6
50°	191.9
52.5°	143.9
55°	109.0
57.5°	82.9
60°	65.4
62.5°	48.0
65°	39.2
67.5°	30.5
70°	21.8
72.5°	17.4
75°	13.1
77.5°	8.7
80°	4.4
82.5°	4.4
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)