

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P202856

Luminaire Tested: **LSR6B40D010BZ EC6B30509030 6LBWWH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202856
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LSR6B40D010BZ EC6B30509030 6LBWWH1
Description: PORTFOLIO 6IN CYLINDER
WIDE DISTRIBUTION WITH WHEAT TRIM
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57
W DL3-44.71 W DLE-39.33 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3262.0 lumens
Efficiency: N/A
Efficacy: 78.0 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.18
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 41.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202856

CATALOG NUMBER: LSR6B40D010BZ EC6B30509030 6LBWWH1

Luminous Intensity Polar Plot





TEST NUMBER: P202856

CATALOG NUMBER: LSR6B40D010BZ EC6B30509030 6LBWWH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	113	109	107	104	110	107	105	102	103	101	99	99	98	96	96	95	93	92		
2	106	100	96	92	104	98	94	91	95	92	89	92	89	87	89	87	85	83		
3	99	92	86	81	97	90	85	81	88	83	79	85	81	78	83	80	77	75		
4	93	84	78	73	91	83	77	72	81	76	71	79	74	71	77	73	70	68		
5	87	77	71	66	85	76	70	65	75	69	65	73	68	64	71	67	63	62		
6	82	71	64	59	80	71	64	59	69	63	59	67	62	58	66	61	58	56		
7	77	66	59	54	75	65	59	54	64	58	54	63	57	53	61	57	53	51		
8	72	61	54	49	71	61	54	49	59	53	49	58	53	49	57	52	49	47		
9	68	57	50	45	67	56	50	45	55	49	45	54	49	45	53	48	45	43		
10	64	53	46	42	63	53	46	42	52	46	42	51	45	42	50	45	41	40		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202856

CATALOG NUMBER: LSR6B40D010BZ EC6B30509030 6LBWWH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	194.7	6.0
10°-20°	579.1	17.8
20°-30°	871.7	26.7
30°-40°	891.3	27.3
40°-50°	541.3	16.6
50°-60°	152.4	4.7
60°-70°	23.2	0.7
70°-80°	7.6	0.2
80°-90°	0.6	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1645.6	50.4
0°-40°	2536.9	77.8
0°-60°	3230.6	99.0
0°-90°	3262.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3262.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2026	
5°	2034	195
15°	2051	579
25°	1903	872
35°	1445	891
45°	696	541
55°	151	152
65°	20	23
75°	8	8
85°	0	1
90°	0	



TEST NUMBER: P202856

CATALOG NUMBER: LSR6B40D010BZ EC6B30509030 6LBWWH1

CANDELA DISTRIBUTION (FULL):

0°	
0°	2026.0
2.5°	2026.0
5°	2034.2
7.5°	2046.5
10°	2046.5
12.5°	2054.7
15°	2050.6
17.5°	2042.4
20°	2013.7
22.5°	1972.8
25°	1903.2
27.5°	1825.5
30°	1719.0
32.5°	1592.2
35°	1444.8
37.5°	1281.1
40°	1092.8
42.5°	896.4
45°	695.8
47.5°	515.7
50°	364.3
52.5°	245.6
55°	151.4
57.5°	90.0
60°	45.0
62.5°	28.7
65°	20.5
67.5°	16.4
70°	12.3
72.5°	8.2
75°	8.2
77.5°	4.1
80°	4.1
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)