

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: io LED

Report Number: P179730

Luminaire Tested: **LDA6A65935D010TE LARH40FL 6LA1LI**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P179730
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P26677)
Test Lab: INNOVATION CENTER-P2
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: io LED
Catalog Number: LDA6A65935D010TE LARH40FL 6LA1LI
Description: PORTFOLIO 6" Adjustable Reflector, Angle-cut Trim, Self-flanged, 40° Flood
Light Source: (1) HIGH LUMEN LED 90CRI / 3500K CCT
Ballast/Driver: ELECTRONIC DRIVER

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 5808.1 lumens
Efficiency: N/A
Efficacy: 74.5 lumens/watt
Spacing Criteria (0/90/45): 0.66 / 0.66 / 0.61
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 78
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P179730
CATALOG NUMBER: LDA6A65935D010TE LARH40FL 6LA1LI

Luminous Intensity Polar Plot





TEST NUMBER: P179730

CATALOG NUMBER: LDA6A65935D010TE LARH40FL 6LA1LI

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	115	112	110	109	112	110	108	107	106	105	104	103	101	100	99	98	98	96	96	96	96
2	110	107	103	101	108	105	102	100	102	99	97	99	97	95	96	95	93	92	92	92	92
3	107	101	98	94	105	100	97	94	98	95	92	95	93	91	93	91	89	88	88	88	88
4	103	97	93	89	101	96	92	89	94	90	88	92	89	87	90	88	86	85	85	85	85
5	99	93	88	85	98	92	88	84	90	87	84	89	85	83	87	85	82	81	81	81	81
6	96	89	84	81	94	88	84	81	87	83	80	85	82	80	84	81	79	78	78	78	78
7	92	85	81	77	91	85	80	77	84	80	77	82	79	76	81	78	76	75	75	75	75
8	89	82	77	74	88	82	77	74	81	77	74	80	76	74	79	76	73	72	72	72	72
9	86	79	74	71	85	79	74	71	78	74	71	77	73	71	76	73	71	70	70	70	70
10	84	76	72	69	83	76	71	69	75	71	68	74	71	68	74	70	68	67	67	67	67

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	824068
5°	717432
10°	648223
15°	592302
20°	433717
25°	214022
30°	47520
35°	9624
40°	1603
45°	473
50°	85
55°	96
60°	110
65°	130
70°	160
75°	0
80°	0
85°	0



TEST NUMBER: P179730

CATALOG NUMBER: LDA6A65935D010TE LARH40FL 6LA1LI

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	1208.5	20.8
10°-20°	2804.2	48.3
20°-30°	1644.9	28.3
30°-40°	142.3	2.5
40°-50°	6.2	0.1
50°-60°	0.9	0.0
60°-70°	1.0	0.0
70°-80°	0.1	0.0
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	5657.5	97.4
0°-40°	5799.8	99.9
0°-60°	5806.9	100.0
0°-90°	5808.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5808.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	15032	
5°	13037	###
15°	10436	2804
25°	3538	1645
35°	144	142
45°	6	6
55°	1	1
65°	1	1
75°	0	0
85°	0	0
90°	0	



TEST NUMBER: P179730

CATALOG NUMBER: LDA6A65935D010TE LARH40FL 6LA1LI

CANDELA DISTRIBUTION (FULL):

0°	
0°	15032.2
2.5°	14125.5
5°	13037.2
7.5°	12313.0
10°	11644.9
12.5°	11089.1
15°	10436.3
17.5°	9308.2
20°	7434.5
22.5°	5376.2
25°	3538.3
27.5°	1994.0
30°	750.7
32.5°	387.6
35°	143.8
37.5°	43.9
40°	22.4
42.5°	12.2
45°	6.1
47.5°	3.1
50°	1.0
52.5°	1.0
55°	1.0
57.5°	1.0
60°	1.0
62.5°	1.0
65°	1.0
67.5°	1.0
70°	1.0
72.5°	0.0
75°	0.0
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)