

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204248

Luminaire Tested: **LE\_6B10D010 EC6B10209040 6LBSWH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P204248  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B10D010 EC6B10209040 6LBSWH1  
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT  
SHALLOW DISTRIBUTION WITH WHEAT TRIM  
WATTAGE D010TR-10.05 W DE010-10.58 W D5LT-10.2 W DMX-10.6 W DL2-11.8 W  
DL3-11.1 W DLE-11.39 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1207.0 lumens  
Efficiency: N/A  
Efficacy: 121.9 lumens/watt  
Spacing Criteria (0/90/45): 0.94 / 0.94 / 1.08  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 9.9  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P204248

CATALOG NUMBER: LE\_6B10D010 EC6B10209040 6LBSWH1

### Luminous Intensity Polar Plot





TEST NUMBER: P204248

CATALOG NUMBER: LE\_6B10D010 EC6B10209040 6LBSWH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	111	107	104	101	108	105	102	99	101	98	96	97	95	93	94	92	90	89			
2	103	96	90	85	100	94	89	85	91	86	83	88	84	81	85	82	79	77			
3	95	86	79	73	93	84	78	73	82	76	72	79	74	70	76	73	69	67			
4	88	77	70	64	86	76	69	63	74	68	63	72	66	62	69	65	61	59			
5	81	70	62	56	79	69	62	56	67	60	55	65	59	55	63	58	54	52			
6	76	64	56	50	74	63	55	50	61	54	49	60	54	49	58	53	49	47			
7	71	58	51	45	69	58	50	45	56	49	45	55	49	44	54	48	44	42			
8	66	54	46	41	65	53	46	41	52	45	40	51	45	40	50	44	40	38			
9	62	50	42	37	61	49	42	37	48	41	37	47	41	37	46	41	37	35			
10	58	46	39	34	57	46	39	34	45	38	34	44	38	34	43	38	34	32			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P204248

CATALOG NUMBER: LE\_6B10D010 EC6B10209040 6LBSWH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	66.4	5.5
10°-20°	171.9	14.2
20°-30°	224.8	18.6
30°-40°	238.0	19.7
40°-50°	222.0	18.4
50°-60°	168.2	13.9
60°-70°	91.1	7.5
70°-80°	24.4	2.0
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	463.0	38.4
0°-40°	701.0	58.1
0°-60°	1091.2	90.4
0°-90°	1207.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1207.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	720	
5°	709	66
15°	614	172
25°	489	225
35°	380	238
45°	289	222
55°	189	168
65°	91	91
75°	21	24
85°	0	0
90°	0	



TEST NUMBER: P204248

CATALOG NUMBER: LE\_6B10D010 EC6B10209040 6LBSWH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	719.9
2.5°	717.2
5°	709.4
7.5°	692.1
10°	669.8
12.5°	643.2
15°	614.2
17.5°	581.2
20°	552.1
22.5°	519.1
25°	488.8
27.5°	458.4
30°	429.2
32.5°	404.2
35°	380.4
37.5°	356.6
40°	334.1
42.5°	311.8
45°	289.2
47.5°	264.1
50°	239.1
52.5°	214.0
55°	188.9
57.5°	162.5
60°	137.4
62.5°	113.6
65°	91.1
67.5°	70.0
70°	51.5
72.5°	35.6
75°	21.1
77.5°	9.2
80°	2.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)