

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202934

Luminaire Tested: **LE\_6B20D010 EC6B10209035 6LBWGPH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P202934  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B20D010 EC6B10209035 6LBWGPH1  
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT  
WIDE DISTRIBUTIONWITH GRAPHITE HAZE TRIM  
WATTAGE D010TR-21.86 W DE010-20.46 W D5LT-21.24 W DMX-20.89 W DL2-22.5 W  
DL3-21.8 6 W DLE-22.46 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1469.1 lumens  
Efficiency: N/A  
Efficacy: 70.6 lumens/watt  
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.11  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 20.8  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P202934

CATALOG NUMBER: LE\_6B20D010 EC6B10209035 6LBWGPH1

### Luminous Intensity Polar Plot





TEST NUMBER: P202934

CATALOG NUMBER: LE\_6B20D010 EC6B10209035 6LBWGPH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	112	109	106	104	110	107	104	102	103	101	99	99	98	96	96	94	93	91				91
2	106	100	95	91	103	98	94	90	95	91	88	92	89	86	89	86	84	82				82
3	99	91	85	81	97	90	84	80	87	82	79	85	81	77	82	79	76	74				74
4	93	84	77	72	91	82	76	72	80	75	71	78	74	70	76	72	69	67				67
5	87	77	70	65	85	76	69	65	74	68	64	72	67	63	71	66	63	61				61
6	81	71	64	59	80	70	63	59	68	62	58	67	62	58	65	61	57	56				56
7	76	65	58	53	75	65	58	53	63	57	53	62	57	53	61	56	52	51				51
8	72	61	54	49	70	60	53	49	59	53	49	58	52	48	57	52	48	47				47
9	68	57	50	45	66	56	49	45	55	49	45	54	48	45	53	48	44	43				43
10	64	53	46	42	63	52	46	42	51	45	41	51	45	41	50	45	41	40				40

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P202934

CATALOG NUMBER: LE\_6B20D010 EC6B10209035 6LBWGPH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	94.1	6.4
10°-20°	263.8	18.0
20°-30°	377.4	25.7
30°-40°	376.2	25.6
40°-50°	239.6	16.3
50°-60°	88.3	6.0
60°-70°	22.1	1.5
70°-80°	6.6	0.5
80°-90°	1.0	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	735.3	50.0
0°-40°	1111.5	75.7
0°-60°	1439.4	98.0
0°-90°	1469.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1469.1	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	998	
5°	994	94
15°	938	264
25°	824	377
35°	612	376
45°	308	240
55°	94	88
65°	20	22
75°	5	7
85°	0	1
90°	0	



TEST NUMBER: P202934

CATALOG NUMBER: LE\_6B20D010 EC6B10209035 6LBWGPH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	998.5
2.5°	998.5
5°	993.5
7.5°	983.4
10°	970.8
12.5°	955.5
15°	937.9
17.5°	915.1
20°	889.9
22.5°	862.0
25°	824.1
27.5°	783.6
30°	730.6
32.5°	675.0
35°	611.8
37.5°	535.9
40°	457.5
42.5°	381.8
45°	308.4
47.5°	242.6
50°	182.0
52.5°	134.0
55°	93.5
57.5°	60.6
60°	40.5
62.5°	27.8
65°	20.2
67.5°	15.1
70°	12.6
72.5°	7.6
75°	5.0
77.5°	5.0
80°	2.5
82.5°	2.5
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)