

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P203136

Luminaire Tested: **LE\_6B20D010 EC6B10208050 6LBWMW1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P203136  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B20D010 EC6B10208050 6LBWMW1  
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT  
WIDE DISTRIBUTION WITH MATTE WHITE TRIM  
WATTAGE D010TR-21.86 W DE010-20.46 W D5LT-21.24 W DMX-20.89 W DL2-22.5 W  
DL3-21.8 6 W DLE-22.46 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2493.1 lumens  
Efficiency: N/A  
Efficacy: 119.9 lumens/watt  
Spacing Criteria (0/90/45): 1.13 / 1.13 / 1.15  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 20.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P203136

CATALOG NUMBER: LE\_6B20D010 EC6B10208050 6LBWMW1

### Luminous Intensity Polar Plot





TEST NUMBER: P203136

CATALOG NUMBER: LE\_6B20D010 EC6B10208050 6LBWMW1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	107	104	100	108	105	102	99	101	98	96	97	95	93	93	92	90	88			88
2	103	96	90	86	100	94	89	85	91	86	83	88	84	81	85	82	79	77			77
3	95	86	80	74	93	85	79	74	82	77	72	80	75	71	77	73	70	68			68
4	89	78	71	65	86	77	70	65	75	69	64	72	67	63	70	66	62	60			60
5	82	71	64	58	80	70	63	58	68	62	57	66	61	56	65	60	56	54			54
6	77	65	57	52	75	64	57	52	63	56	51	61	55	51	60	54	50	49			49
7	72	60	52	47	70	59	52	47	58	51	46	56	50	46	55	50	46	44			44
8	67	55	48	42	66	55	47	42	53	47	42	52	46	42	51	46	42	40			40
9	63	51	44	39	62	51	44	39	50	43	39	49	43	38	48	42	38	37			37
10	60	48	40	36	58	47	40	36	46	40	36	45	40	35	45	39	35	34			34

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P203136

CATALOG NUMBER: LE\_6B20D010 EC6B10208050 6LBWMW1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	131.9	5.3
10°-20°	369.8	14.8
20°-30°	532.8	21.4
30°-40°	553.2	22.2
40°-50°	409.0	16.4
50°-60°	244.3	9.8
60°-70°	148.4	6.0
70°-80°	81.3	3.3
80°-90°	22.6	0.9
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1034.4	41.5
0°-40°	1587.5	63.7
0°-60°	2240.8	89.9
0°-90°	2493.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2493.1	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	1400	
5°	1391	132
15°	1312	370
25°	1161	533
35°	892	553
45°	526	409
55°	266	244
65°	148	148
75°	76	81
85°	18	23
90°	0	



TEST NUMBER: P203136

CATALOG NUMBER: LE\_6B20D010 EC6B10208050 6LBWMW1

**CANDELA DISTRIBUTION (FULL):**

0°	
0°	1400.1
2.5°	1400.1
5°	1391.0
7.5°	1378.9
10°	1360.8
12.5°	1339.6
15°	1312.4
17.5°	1282.1
20°	1251.9
22.5°	1209.5
25°	1161.1
27.5°	1109.8
30°	1043.2
32.5°	976.8
35°	892.0
37.5°	804.4
40°	707.6
42.5°	613.9
45°	526.1
47.5°	447.5
50°	378.0
52.5°	317.5
55°	266.1
57.5°	226.8
60°	193.5
62.5°	169.4
65°	148.1
67.5°	130.0
70°	111.9
72.5°	93.8
75°	75.6
77.5°	60.5
80°	45.4
82.5°	33.2
85°	18.1
87.5°	9.1
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)