

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P205418

Luminaire Tested: **LE_6B30D010 EC6B30509730 6LBSLI1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205418
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B30D010 EC6B30509730 6LBSLI1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH SPECULAR CLEAR TRIM
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W
DL3-29.67 W DLE-29.73 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2972.8 lumens
Efficiency: N/A
Efficacy: 106.2 lumens/watt
Spacing Criteria (0/90/45): 0.91 / 0.91 / 1.04
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205418

CATALOG NUMBER: LE_6B30D010 EC6B30509730 6LBSLI1

Luminous Intensity Polar Plot





TEST NUMBER: P205418

CATALOG NUMBER: LE_6B30D010 EC6B30509730 6LBSLI1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	111	107	104	101	109	105	102	99	101	99	96	97	95	93	94	92	91	89			
2	103	96	91	86	100	94	89	85	91	87	83	88	84	81	85	82	79	77			
3	95	86	79	74	93	85	78	73	82	76	72	79	75	71	77	73	70	68			
4	88	78	70	64	86	77	69	64	74	68	63	72	67	62	70	65	62	60			
5	82	71	63	57	80	70	62	57	67	61	56	66	60	55	64	59	55	53			
6	76	64	56	51	74	63	56	51	62	55	50	60	54	50	59	53	49	47			
7	71	59	51	46	70	58	51	45	57	50	45	55	49	45	54	49	45	43			
8	67	54	47	41	65	54	46	41	52	46	41	51	45	41	50	45	41	39			
9	63	50	43	38	61	50	43	38	49	42	38	48	42	37	47	41	37	36			
10	59	47	40	35	58	46	39	35	45	39	35	45	39	34	44	38	34	33			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205418

CATALOG NUMBER: LE_6B30D010 EC6B30509730 6LBSLI1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	172.9	5.8
10°-20°	440.1	14.8
20°-30°	561.2	18.9
30°-40°	582.0	19.6
40°-50°	536.3	18.0
50°-60°	403.4	13.6
60°-70°	217.7	7.3
70°-80°	58.4	2.0
80°-90°	0.9	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1174.2	39.5
0°-40°	1756.1	59.1
0°-60°	2695.8	90.7
0°-90°	2972.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2972.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1876	
5°	1848	173
15°	1570	440
25°	1219	561
35°	928	582
45°	698	536
55°	452	403
65°	218	218
75°	50	58
85°	0	1
90°	0	



TEST NUMBER: P205418

CATALOG NUMBER: LE_6B30D010 EC6B30509730 6LBSLI1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1876.0
2.5°	1869.6
5°	1847.5
7.5°	1806.5
10°	1733.9
12.5°	1661.2
15°	1569.6
17.5°	1484.4
20°	1395.9
22.5°	1304.4
25°	1219.1
27.5°	1137.0
30°	1061.1
32.5°	991.6
35°	928.5
37.5°	868.5
40°	811.6
42.5°	751.6
45°	698.0
47.5°	638.0
50°	578.0
52.5°	514.8
55°	451.6
57.5°	388.5
60°	328.5
62.5°	271.6
65°	217.9
67.5°	167.4
70°	123.1
72.5°	85.2
75°	50.5
77.5°	22.1
80°	6.4
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)