

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204076

Luminaire Tested: **LE_6B30D010 EC6B30508050 6LBNMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204076
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B30D010 EC6B30508050 6LBNMW1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
NARROW DISTRIBUTION WITH MATTE WHITE TRIM
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W
DL3-29.67 W DLE-29.73 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 2760.2 lumens
Efficiency: N/A
Efficacy: 98.6 lumens/watt
Spacing Criteria (0/90/45): 0.99 / 0.99 / 0.97
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204076

CATALOG NUMBER: LE_6B30D010 EC6B30508050 6LBNMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204076

CATALOG NUMBER: LE_6B30D010 EC6B30508050 6LBNMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	112	108	105	103	109	106	103	101	102	100	98	98	97	95	95	93	92	90			
2	105	99	94	90	102	97	92	89	94	90	87	91	87	85	88	85	83	81			
3	98	90	84	79	96	89	83	79	86	81	77	84	80	76	81	78	75	73			
4	92	83	76	71	90	82	76	71	80	74	70	77	73	69	75	71	68	66			
5	87	77	70	64	85	76	69	64	74	68	64	72	67	63	70	66	62	61			
6	81	71	64	59	80	70	63	59	68	63	58	67	62	58	66	61	57	56			
7	77	66	59	54	75	65	59	54	64	58	54	63	57	53	61	57	53	51			
8	72	61	55	50	71	61	54	50	60	54	49	59	53	49	58	53	49	47			
9	69	58	51	46	67	57	51	46	56	50	46	55	50	46	54	49	46	44			
10	65	54	47	43	64	54	47	43	53	47	43	52	46	43	51	46	43	41			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204076

CATALOG NUMBER: LE_6B30D010 EC6B30508050 6LBNMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	210.2	7.6
10°-20°	557.2	20.2
20°-30°	743.8	26.9
30°-40°	600.1	21.7
40°-50°	287.6	10.4
50°-60°	170.5	6.2
60°-70°	113.3	4.1
70°-80°	60.7	2.2
80°-90°	16.7	0.6
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1511.2	54.7
0°-40°	2111.3	76.5
0°-60°	2569.4	93.1
0°-90°	2760.2	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2760.2	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2264	
5°	2237	210
15°	1983	557
25°	1628	744
35°	961	600
45°	355	288
55°	189	170
65°	114	113
75°	57	61
85°	13	17
90°	0	



TEST NUMBER: P204076

CATALOG NUMBER: LE_6B30D010 EC6B30508050 6LBNMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2263.6
2.5°	2263.6
5°	2237.2
7.5°	2193.4
10°	2132.0
12.5°	2066.2
15°	1982.9
17.5°	1903.9
20°	1816.1
22.5°	1724.0
25°	1627.5
27.5°	1526.6
30°	1381.9
32.5°	1180.0
35°	960.8
37.5°	758.9
40°	587.9
42.5°	456.2
45°	355.4
47.5°	280.8
50°	236.9
52.5°	210.6
55°	188.6
57.5°	171.1
60°	149.1
62.5°	131.6
65°	114.0
67.5°	96.5
70°	83.4
72.5°	70.2
75°	57.0
77.5°	43.9
80°	35.1
82.5°	26.4
85°	13.1
87.5°	4.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)