

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204805

Luminaire Tested: **LE_6B30D010 EC6B30509050 6LBCSMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204805
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B30D010 EC6B30509050 6LBCSMW1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH CAST MATTE WHITE TRIM
WATTAGE D010TR-27.4 W DE010-27.95 W D5LT-27.65 W DMX-27.73 W DL2-29.56 W
DL3-29.67 W DLE-29.73 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3535.8 lumens
Efficiency: N/A
Efficacy: 126.3 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 28
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204805

CATALOG NUMBER: LE_6B30D010 EC6B30509050 6LBCSMW1

Luminous Intensity Polar Plot





TEST NUMBER: P204805

CATALOG NUMBER: LE_6B30D010 EC6B30509050 6LBCSMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				20	
RC	80				70				50				30				10				0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0	
RCR																						
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100				100
1	110	106	102	99	108	104	100	97	100	97	94	96	93	91	92	90	89	87				87
2	101	94	87	82	99	92	86	81	88	84	79	85	81	78	82	79	76	74				74
3	93	83	75	70	90	81	74	69	79	73	68	76	71	67	73	69	65	63				63
4	85	74	66	60	83	73	65	59	70	64	58	68	62	58	66	61	57	55				55
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48				48
6	73	60	52	45	71	59	51	45	57	50	45	56	49	44	54	49	44	42				42
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	50	44	39	37				37
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	33				33
9	59	46	38	33	57	45	38	32	44	37	32	43	37	32	42	36	32	30				30
10	55	42	35	30	54	42	34	30	41	34	29	40	34	29	39	33	29	27				27

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204805

CATALOG NUMBER: LE_6B30D010 EC6B30509050 6LBCSMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	136.8	3.9
10°-20°	389.5	11.0
20°-30°	586.0	16.6
30°-40°	694.4	19.6
40°-50°	691.1	19.5
50°-60°	557.1	15.8
60°-70°	337.0	9.5
70°-80°	125.2	3.5
80°-90°	18.7	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1112.3	31.5
0°-40°	1806.8	51.1
0°-60°	3055.0	86.4
0°-90°	3535.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	3535.8	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1444	
5°	1438	137
15°	1380	390
25°	1273	586
35°	1112	694
45°	900	691
55°	621	557
65°	338	337
75°	114	125
85°	15	19
90°	0	



TEST NUMBER: P204805

CATALOG NUMBER: LE_6B30D010 EC6B30509050 6LBCSMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	1444.1
2.5°	1444.1
5°	1437.6
7.5°	1433.4
10°	1420.5
12.5°	1399.1
15°	1379.9
17.5°	1358.4
20°	1332.8
22.5°	1307.0
25°	1272.8
27.5°	1236.2
30°	1195.6
32.5°	1157.0
35°	1112.0
37.5°	1064.9
40°	1009.1
42.5°	955.6
45°	899.9
47.5°	837.8
50°	769.2
52.5°	698.5
55°	621.4
57.5°	552.8
60°	475.6
62.5°	407.1
65°	338.5
67.5°	274.2
70°	214.2
72.5°	160.8
75°	113.5
77.5°	72.9
80°	42.9
82.5°	25.8
85°	15.0
87.5°	6.4
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)