

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P205025

Luminaire Tested: **LE_6B40D010 EC6B30509730 6LBCS1MMS**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205025
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B40D010 EC6B30509730 6LBCS1MMS
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH CAST MATTE METALLIC SILVER TRIM
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57
W DL3-44.71 W DLE-39.33 W
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4009.4 lumens
Efficiency: N/A
Efficacy: 95.9 lumens/watt
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.27
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 41.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205025

CATALOG NUMBER: LE_6B40D010 EC6B30509730 6LBCS1MMS

Luminous Intensity Polar Plot





TEST NUMBER: P205025

CATALOG NUMBER: LE_6B40D010 EC6B30509730 6LBCS1MMS

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	107	103	100	108	105	101	98	100	98	95	97	94	92	93	91	90	88			88
2	102	95	89	84	99	93	88	83	90	85	81	86	83	79	83	80	78	76			76
3	94	85	77	72	92	83	76	71	80	74	70	77	73	69	75	71	67	65			65
4	87	76	68	62	84	74	67	61	72	66	61	70	64	60	68	63	59	57			57
5	80	68	60	54	78	67	59	54	65	58	53	63	57	53	61	56	52	50			50
6	74	62	54	48	72	61	53	47	59	52	47	58	51	47	56	51	46	44			44
7	69	56	48	42	67	56	48	42	54	47	42	53	46	42	51	46	41	40			40
8	64	52	44	38	63	51	43	38	50	43	38	48	42	38	47	42	37	36			36
9	60	48	40	35	59	47	40	34	46	39	34	45	39	34	44	38	34	32			32
10	57	44	36	31	55	43	36	31	43	36	31	42	35	31	41	35	31	29			29

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205025

CATALOG NUMBER: LE_6B40D010 EC6B30509730 6LBCS1MMS

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	173.5	4.3
10°-20°	486.9	12.1
20°-30°	711.1	17.7
30°-40°	813.4	20.3
40°-50°	781.7	19.5
50°-60°	603.6	15.1
60°-70°	336.9	8.4
70°-80°	98.1	2.4
80°-90°	4.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1371.5	34.2
0°-40°	2184.9	54.5
0°-60°	3570.2	89.0
0°-90°	4009.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4009.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1841	
5°	1826	174
15°	1727	487
25°	1546	711
35°	1302	813
45°	1019	782
55°	677	604
65°	337	337
75°	86	98
85°	3	4
90°	0	



TEST NUMBER: P205025

CATALOG NUMBER: LE_6B40D010 EC6B30509730 6LBCS1MMS

CANDELA DISTRIBUTION (FULL):

	0°
0°	1841.2
2.5°	1841.2
5°	1825.6
7.5°	1817.9
10°	1792.0
12.5°	1760.9
15°	1727.1
17.5°	1693.4
20°	1644.1
22.5°	1605.2
25°	1545.6
27.5°	1486.0
30°	1426.2
32.5°	1366.6
35°	1301.9
37.5°	1237.0
40°	1161.8
42.5°	1094.4
45°	1019.1
47.5°	933.6
50°	853.1
52.5°	765.0
55°	676.9
57.5°	586.1
60°	500.5
62.5°	414.9
65°	337.1
67.5°	264.5
70°	197.1
72.5°	137.5
75°	85.6
77.5°	44.1
80°	15.5
82.5°	5.1
85°	2.6
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)