

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202756

Luminaire Tested: **LE\_6B40D010 EC6B30509050 6LBWH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P202756  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B40D010 EC6B30509050 6LBWH1  
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT  
WIDE DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM  
WATTAGE D010TR-43.02 W DE010-42.54 W D5LT-42.539 W DMX-41.87 W DL2-41.57  
W DL3-44.71 W DLE-39.33 W  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 4025.4 lumens  
Efficiency: N/A  
Efficacy: 96.3 lumens/watt  
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.16  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 41.8  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P202756

CATALOG NUMBER: LE\_6B40D010 EC6B30509050 6LBWH1

### Luminous Intensity Polar Plot





TEST NUMBER: P202756

CATALOG NUMBER: LE\_6B40D010 EC6B30509050 6LBWH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	112	109	106	103	110	107	104	101	103	100	98	99	97	95	95	94	93	91			
2	105	99	94	90	103	97	93	89	94	90	87	91	88	85	88	85	83	81			
3	98	90	84	79	96	89	83	78	86	81	77	83	79	76	81	78	75	73			
4	92	82	75	70	90	81	75	70	79	73	69	77	72	68	75	71	67	65			
5	86	75	68	63	84	74	68	63	72	66	62	71	65	61	69	64	61	59			
6	80	69	62	57	78	68	61	56	67	61	56	65	60	56	64	59	55	53			
7	75	64	56	51	73	63	56	51	62	55	51	60	55	51	59	54	50	49			
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44			
9	66	55	48	43	65	54	47	43	53	47	43	52	47	42	51	46	42	41			
10	62	51	44	40	61	50	44	39	50	43	39	49	43	39	48	43	39	38			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P202756

CATALOG NUMBER: LE\_6B40D010 EC6B30509050 6LBWH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	234.5	5.8
10°-20°	665.4	16.5
20°-30°	975.6	24.2
30°-40°	1015.3	25.2
40°-50°	702.5	17.5
50°-60°	305.9	7.6
60°-70°	93.8	2.3
70°-80°	28.1	0.7
80°-90°	4.2	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1875.5	46.6
0°-40°	2890.8	71.8
0°-60°	3899.2	96.9
0°-90°	4025.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4025.4	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2483	
5°	2472	234
15°	2363	665
25°	2133	976
35°	1643	1015
45°	908	703
55°	329	306
65°	89	94
75°	26	28
85°	5	4
90°	0	



TEST NUMBER: P202756

CATALOG NUMBER: LE\_6B40D010 EC6B30509050 6LBWH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2482.8
2.5°	2488.0
5°	2472.4
7.5°	2451.5
10°	2425.4
12.5°	2399.4
15°	2362.9
17.5°	2315.9
20°	2263.8
22.5°	2206.4
25°	2133.4
27.5°	2039.4
30°	1919.5
32.5°	1794.2
35°	1643.0
37.5°	1476.1
40°	1283.1
42.5°	1090.1
45°	907.6
47.5°	735.5
50°	584.1
52.5°	443.4
55°	328.6
57.5°	234.8
60°	161.8
62.5°	120.0
65°	88.6
67.5°	67.8
70°	47.0
72.5°	36.5
75°	26.1
77.5°	15.6
80°	10.4
82.5°	5.2
85°	5.2
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)