

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P205132

Luminaire Tested: **LE_6B50D010R EC6B30509024 6LBMLI1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P205132
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B50D010R EC6B30509024 6LBML1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH SPECULAR CLEAR TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4320.0 lumens
Efficiency: N/A
Efficacy: 73.5 lumens/watt
Spacing Criteria (0/90/45): 0.85 / 0.85 / 0.85
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P205132

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBML11

Luminous Intensity Polar Plot





TEST NUMBER: P205132

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBML11

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10		0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100		
1	114	111	109	106	111	109	107	105	105	103	101	101	100	98	98	97	96	94		
2	108	103	100	96	106	102	98	95	99	96	93	96	93	91	93	91	89	88		
3	103	97	92	88	101	95	91	87	93	89	86	90	87	85	88	85	83	82		
4	98	91	85	81	96	89	84	81	87	83	80	85	82	79	83	80	78	76		
5	93	85	79	75	91	84	79	75	82	78	74	81	77	73	79	76	73	71		
6	89	80	74	70	87	79	74	70	78	73	69	76	72	69	75	71	68	67		
7	84	75	69	65	83	75	69	65	73	68	65	72	68	64	71	67	64	63		
8	80	71	65	61	79	70	65	61	69	64	61	68	64	60	67	63	60	59		
9	77	67	61	57	75	67	61	57	66	61	57	65	60	57	64	60	57	55		
10	73	64	58	54	72	63	58	54	62	57	54	62	57	54	61	57	54	52		

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P205132

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBML11

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	498.0	11.5
10°-20°	1240.0	28.7
20°-30°	1441.4	33.4
30°-40°	882.7	20.4
40°-50°	219.2	5.1
50°-60°	25.6	0.6
60°-70°	9.5	0.2
70°-80°	3.6	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	3179.4	73.6
0°-40°	4062.0	94.0
0°-60°	4306.9	99.7
0°-90°	4320.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4320.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	5406	
5°	5334	498
15°	4450	1240
25°	3190	1441
35°	1382	883
45°	243	219
55°	22	26
65°	11	9
75°	6	4
85°	0	0
90°	0	



TEST NUMBER: P205132

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBML11

CANDELA DISTRIBUTION (FULL):

0°	
0°	5406.4
2.5°	5400.9
5°	5334.5
7.5°	5190.8
10°	4997.2
12.5°	4743.0
15°	4450.0
17.5°	4134.9
20°	3825.4
22.5°	3515.8
25°	3189.6
27.5°	2813.8
30°	2382.5
32.5°	1879.5
35°	1382.0
37.5°	972.9
40°	663.4
42.5°	414.6
45°	243.2
47.5°	138.2
50°	71.9
52.5°	33.1
55°	22.1
57.5°	16.6
60°	16.6
62.5°	11.0
65°	11.0
67.5°	5.5
70°	5.5
72.5°	5.5
75°	5.5
77.5°	0.0
80°	0.0
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)