

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202764

Luminaire Tested: **LE_6B50D010R EC6B30509024 6LBWH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P202764
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B50D010R EC6B30509024 6LBWH1
Description: PORTFOLIO 6 INCH 60 DEGREE CUTOFF RECESSED DOWNLIGHT
WIDE DISTRIBUTION WITH SEMI-SPECULAR CLEAR TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 4270.3 lumens
Efficiency: N/A
Efficacy: 72.6 lumens/watt
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.16
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P202764

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBWH1

Luminous Intensity Polar Plot





TEST NUMBER: P202764

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBWH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			
1	112	109	106	103	110	107	104	101	103	100	98	99	97	95	95	94	93	91			
2	105	99	94	90	103	97	93	89	94	90	87	91	88	85	88	85	83	81			
3	98	90	84	79	96	89	83	78	86	81	77	83	79	76	81	78	75	73			
4	92	82	75	70	90	81	75	70	79	73	69	77	72	68	75	71	67	65			
5	86	75	68	63	84	74	68	63	72	66	62	71	65	61	69	64	61	59			
6	80	69	62	57	78	68	61	56	67	61	56	65	60	56	64	59	55	53			
7	75	64	56	51	73	63	56	51	62	55	51	60	55	51	59	54	50	49			
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44			
9	66	55	48	43	65	54	47	43	53	47	43	52	47	42	51	46	42	41			
10	62	51	44	40	61	50	44	39	50	43	39	49	43	39	48	43	39	38			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P202764

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBWH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	248.8	5.8
10°-20°	705.9	16.5
20°-30°	1034.9	24.2
30°-40°	1077.1	25.2
40°-50°	745.3	17.5
50°-60°	324.4	7.6
60°-70°	99.5	2.3
70°-80°	29.8	0.7
80°-90°	4.5	0.1
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1989.6	46.6
0°-40°	3066.7	71.8
0°-60°	4136.4	96.9
0°-90°	4270.3	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	4270.3	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2634	
5°	2623	249
15°	2507	706
25°	2263	1035
35°	1743	1077
45°	963	745
55°	349	324
65°	94	99
75°	28	30
85°	6	4
90°	0	



TEST NUMBER: P202764

CATALOG NUMBER: LE_6B50D010R EC6B30509024 6LBWH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2633.9
2.5°	2639.4
5°	2622.8
7.5°	2600.6
10°	2573.0
12.5°	2545.4
15°	2506.6
17.5°	2456.8
20°	2401.5
22.5°	2340.6
25°	2263.1
27.5°	2163.5
30°	2036.2
32.5°	1903.5
35°	1743.0
37.5°	1565.9
40°	1361.2
42.5°	1156.5
45°	962.8
47.5°	780.2
50°	619.8
52.5°	470.4
55°	348.6
57.5°	249.0
60°	171.5
62.5°	127.2
65°	94.1
67.5°	71.9
70°	49.8
72.5°	38.8
75°	27.6
77.5°	16.6
80°	11.1
82.5°	5.5
85°	5.5
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)