

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204930

Luminaire Tested: **LE_6B50D010R EC6B30509027 6LBCSMB1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204930
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B50D010R EC6B30509027 6LBCSMB1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH CAST MATTE BLACK TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5093.0 lumens
Efficiency: N/A
Efficacy: 86.6 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204930

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBSCMB1

Luminous Intensity Polar Plot





TEST NUMBER: P204930

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBSCMB1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100	100	100	100
1	111	107	103	100	108	104	101	98	100	98	95	96	94	92	93	91	90	88	88	88	88
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75	75	75	75
3	93	84	77	71	91	83	76	70	80	74	69	77	72	68	74	70	67	65	65	65	65
4	86	75	67	61	84	74	66	61	71	65	60	69	63	59	67	62	58	56	56	56	56
5	79	67	59	53	77	66	59	53	64	57	52	62	56	52	61	55	51	49	49	49	49
6	74	61	53	47	72	60	52	46	58	51	46	57	50	46	55	50	45	43	43	43	43
7	68	55	47	41	67	55	47	41	53	46	41	52	45	41	50	45	40	39	39	39	39
8	64	51	43	37	62	50	42	37	49	42	37	48	41	37	46	41	36	35	35	35	35
9	60	47	39	33	58	46	39	33	45	38	33	44	38	33	43	37	33	31	31	31	31
10	56	43	35	30	55	43	35	30	42	35	30	41	34	30	40	34	30	28	28	28	28

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204930

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBSCMB1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	203.4	4.0
10°-20°	579.5	11.4
20°-30°	871.2	17.1
30°-40°	1033.6	20.3
40°-50°	1022.9	20.1
50°-60°	803.5	15.8
60°-70°	450.4	8.8
70°-80°	126.5	2.5
80°-90°	2.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1654.1	32.5
0°-40°	2687.7	52.8
0°-60°	4514.1	88.6
0°-90°	5093.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5093.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2151	
5°	2147	203
15°	2056	580
25°	1891	871
35°	1658	1034
45°	1333	1023
55°	906	803
65°	449	450
75°	110	126
85°	0	2
90°	0	



TEST NUMBER: P204930

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBCSMB1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2150.6
2.5°	2143.2
5°	2146.9
7.5°	2128.6
10°	2106.8
12.5°	2081.2
15°	2055.6
17.5°	2022.8
20°	1979.0
22.5°	1935.1
25°	1891.4
27.5°	1843.9
30°	1781.8
32.5°	1719.8
35°	1657.6
37.5°	1584.6
40°	1500.6
42.5°	1420.4
45°	1332.8
47.5°	1234.1
50°	1131.9
52.5°	1015.0
55°	905.5
57.5°	781.4
60°	664.5
62.5°	558.6
65°	449.1
67.5°	354.1
70°	262.9
72.5°	178.9
75°	109.5
77.5°	54.8
80°	14.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)