

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P203795

Luminaire Tested: **LE_6B50D010R EC6B30509027 6LBNWH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203795
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B50D010R EC6B30509027 6LBNWH1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
NARROW DISTRIBUTION WITH WHEAT TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 3697.0 lumens
Efficiency: N/A
Efficacy: 62.9 lumens/watt
Spacing Criteria (0/90/45): 0.56 / 0.56 / 0.64
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 58.8
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203795

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBNWH1

Luminous Intensity Polar Plot





TEST NUMBER: P203795

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBNWH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 |
| RCR | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | | |
| 1 | 114 | 111 | 109 | 107 | 112 | 109 | 107 | 105 | 105 | 104 | 102 | 101 | 100 | 99 | 98 | 97 | 96 | 94 | | |
| 2 | 109 | 104 | 101 | 97 | 107 | 103 | 99 | 96 | 99 | 97 | 94 | 96 | 94 | 92 | 94 | 92 | 90 | 89 | | |
| 3 | 104 | 98 | 93 | 90 | 102 | 97 | 92 | 89 | 94 | 91 | 88 | 92 | 89 | 86 | 89 | 87 | 85 | 83 | | |
| 4 | 99 | 92 | 87 | 83 | 97 | 91 | 86 | 83 | 89 | 85 | 82 | 87 | 84 | 81 | 85 | 82 | 80 | 79 | | |
| 5 | 95 | 87 | 82 | 78 | 93 | 86 | 81 | 77 | 84 | 80 | 77 | 83 | 79 | 76 | 81 | 78 | 75 | 74 | | |
| 6 | 91 | 82 | 77 | 73 | 89 | 82 | 76 | 73 | 80 | 76 | 72 | 79 | 75 | 72 | 78 | 74 | 71 | 70 | | |
| 7 | 87 | 78 | 73 | 69 | 85 | 77 | 72 | 69 | 76 | 72 | 68 | 75 | 71 | 68 | 74 | 70 | 67 | 66 | | |
| 8 | 83 | 74 | 69 | 65 | 82 | 74 | 68 | 65 | 73 | 68 | 65 | 72 | 67 | 64 | 71 | 67 | 64 | 63 | | |
| 9 | 79 | 71 | 65 | 62 | 78 | 70 | 65 | 61 | 69 | 65 | 61 | 68 | 64 | 61 | 68 | 64 | 61 | 60 | | |
| 10 | 76 | 67 | 62 | 58 | 75 | 67 | 62 | 58 | 66 | 61 | 58 | 65 | 61 | 58 | 65 | 61 | 58 | 57 | | |

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203795

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBNWH1

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 614.4 | 16.6 |
| 10°-20° | 1180.7 | 31.9 |
| 20°-30° | 1073.4 | 29.0 |
| 30°-40° | 650.6 | 17.6 |
| 40°-50° | 148.1 | 4.0 |
| 50°-60° | 18.9 | 0.5 |
| 60°-70° | 8.5 | 0.2 |
| 70°-80° | 2.4 | 0.1 |
| 80°-90° | 0.0 | 0.0 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 2868.4 | 77.6 |
| 0°-40° | 3519.1 | 95.2 |
| 0°-60° | 3686.1 | 99.7 |
| 0°-90° | 3697.0 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 3697.0 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|------|------|
| 0° | 7258 | |
| 5° | 6843 | 614 |
| 15° | 4252 | 1181 |
| 25° | 2327 | 1073 |
| 35° | 1032 | 651 |
| 45° | 164 | 148 |
| 55° | 19 | 19 |
| 65° | 6 | 8 |
| 75° | 0 | 2 |
| 85° | 0 | 0 |
| 90° | 0 | |



TEST NUMBER: P203795

CATALOG NUMBER: LE_6B50D010R EC6B30509027 6LBNWH1

CANDELA DISTRIBUTION (FULL):

| | 0° |
|-------|--------|
| 0° | 7258.4 |
| 2.5° | 7170.4 |
| 5° | 6843.2 |
| 7.5° | 6315.0 |
| 10° | 5642.0 |
| 12.5° | 4943.8 |
| 15° | 4251.9 |
| 17.5° | 3622.9 |
| 20° | 3094.6 |
| 22.5° | 2666.9 |
| 25° | 2327.2 |
| 27.5° | 2025.4 |
| 30° | 1729.8 |
| 32.5° | 1383.8 |
| 35° | 1031.5 |
| 37.5° | 723.4 |
| 40° | 478.0 |
| 42.5° | 295.6 |
| 45° | 163.5 |
| 47.5° | 75.5 |
| 50° | 31.5 |
| 52.5° | 25.1 |
| 55° | 18.9 |
| 57.5° | 18.9 |
| 60° | 12.6 |
| 62.5° | 12.6 |
| 65° | 6.2 |
| 67.5° | 6.2 |
| 70° | 6.2 |
| 72.5° | 6.2 |
| 75° | 0.0 |
| 77.5° | 0.0 |
| 80° | 0.0 |
| 82.5° | 0.0 |
| 85° | 0.0 |
| 87.5° | 0.0 |
| 90° | 0.0 |



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)