

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204942

Luminaire Tested: **LE_6B60D010R EC6B60709024 6LBCSMB1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204942
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B60D010R EC6B60709024 6LBCSMB1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH CAST MATTE BLACK TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5006.1 lumens
Efficiency: N/A
Efficacy: 80.1 lumens/watt
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 62.5
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204942

CATALOG NUMBER: LE_6B60D010R EC6B60709024 6LBSCMB1

Luminous Intensity Polar Plot





TEST NUMBER: P204942

CATALOG NUMBER: LE_6B60D010R EC6B60709024 6LBSCMB1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20				
RC	80				70				50				30				10			0	
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100			100
1	111	107	103	100	108	104	101	98	100	98	95	96	94	92	93	91	90	88			
2	102	95	89	84	99	93	87	83	89	85	81	86	82	79	83	80	77	75			
3	93	84	77	71	91	83	76	70	80	74	69	77	72	68	74	70	67	65			
4	86	75	67	61	84	74	66	61	71	65	60	69	63	59	67	62	58	56			
5	79	67	59	53	77	66	59	53	64	57	52	62	56	52	61	55	51	49			
6	74	61	53	47	72	60	52	46	58	51	46	57	50	46	55	50	45	43			
7	68	55	47	41	67	55	47	41	53	46	41	52	45	41	50	45	40	39			
8	64	51	43	37	62	50	42	37	49	42	37	48	41	37	46	41	36	35			
9	60	47	39	33	58	46	39	33	45	38	33	44	38	33	43	37	33	31			
10	56	43	35	30	55	43	35	30	42	35	30	41	34	30	40	34	30	28			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204942

CATALOG NUMBER: LE_6B60D010R EC6B60709024 6LBSCMB1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	199.9	4.0
10°-20°	569.6	11.4
20°-30°	856.3	17.1
30°-40°	1016.0	20.3
40°-50°	1005.4	20.1
50°-60°	789.7	15.8
60°-70°	442.8	8.8
70°-80°	124.4	2.5
80°-90°	2.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	1625.8	32.5
0°-40°	2641.8	52.8
0°-60°	4437.0	88.6
0°-90°	5006.1	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5006.1	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2114	
5°	2110	200
15°	2020	570
25°	1859	856
35°	1629	1016
45°	1310	1005
55°	890	790
65°	441	443
75°	108	124
85°	0	2
90°	0	



TEST NUMBER: P204942

CATALOG NUMBER: LE_6B60D010R EC6B60709024 6LBCSMB1

CANDELA DISTRIBUTION (FULL):

0°	
0°	2113.9
2.5°	2106.8
5°	2110.2
7.5°	2092.4
10°	2070.8
12.5°	2045.6
15°	2020.5
17.5°	1988.2
20°	1945.2
22.5°	1902.1
25°	1859.0
27.5°	1812.4
30°	1751.4
32.5°	1690.4
35°	1629.4
37.5°	1557.6
40°	1475.0
42.5°	1396.1
45°	1310.0
47.5°	1213.0
50°	1112.6
52.5°	997.8
55°	890.0
57.5°	768.0
60°	653.1
62.5°	549.1
65°	441.4
67.5°	348.1
70°	258.4
72.5°	175.9
75°	107.6
77.5°	53.9
80°	14.4
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)