

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P203603

Luminaire Tested: **LE_6B60D010R EC6B60709030 6LBMMW1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P203603
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B60D010R EC6B60709030 6LBMMW1
Description: PORTFOLIO 6 INCH 50 DEGREE CUTOFF RECESSED DOWNLIGHT
MEDIUM DISTRIBUTION WITH MATTE WHITE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 5112.9 lumens
Efficiency: N/A
Efficacy: 81.8 lumens/watt
Spacing Criteria (0/90/45): 1 / 1 / 0.97
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 62.5
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P203603

CATALOG NUMBER: LE_6B60D010R EC6B60709030 6LBMMW1

Luminous Intensity Polar Plot





TEST NUMBER: P203603

CATALOG NUMBER: LE_6B60D010R EC6B60709030 6LBMMW1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	108	104	101	109	105	103	100	101	99	97	98	96	94	94	92	91	89																			
2	104	97	92	88	101	96	91	87	92	88	85	89	86	83	86	83	81	79																			
3	97	88	82	77	95	87	81	76	84	79	75	82	77	74	79	76	73	71																			
4	90	81	74	68	88	80	73	68	77	72	67	75	70	66	73	69	65	64																			
5	85	74	67	61	83	73	66	61	71	65	61	69	64	60	68	63	59	58																			
6	79	68	61	56	78	68	61	56	66	60	55	64	59	55	63	58	54	53																			
7	75	63	56	51	73	63	56	51	61	55	50	60	54	50	59	54	50	48																			
8	70	59	52	47	69	58	51	47	57	51	46	56	50	46	55	50	46	44																			
9	66	55	48	43	65	54	48	43	53	47	43	52	47	43	51	46	43	41																			
10	63	51	45	40	62	51	44	40	50	44	40	49	44	40	48	43	40	38																			

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P203603

CATALOG NUMBER: LE_6B60D010R EC6B60709030 6LBMMW1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	352.4	6.9
10°-20°	944.0	18.5
20°-30°	1267.5	24.8
30°-40°	1039.7	20.3
40°-50°	624.3	12.2
50°-60°	414.9	8.1
60°-70°	278.2	5.4
70°-80°	149.7	2.9
80°-90°	42.2	0.8
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2563.9	50.1
0°-40°	3603.6	70.5
0°-60°	4642.9	90.8
0°-90°	5112.9	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	5112.9	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	3815	
5°	3752	352
15°	3364	944
25°	2792	1268
35°	1650	1040
45°	790	624
55°	458	415
65°	282	278
75°	141	150
85°	35	42
90°	0	



TEST NUMBER: P203603

CATALOG NUMBER: LE_6B60D010R EC6B60709030 6LBMMW1

CANDELA DISTRIBUTION (FULL):

	0°
0°	3815.0
2.5°	3786.9
5°	3751.6
7.5°	3674.0
10°	3582.4
12.5°	3469.5
15°	3363.8
17.5°	3236.8
20°	3109.9
22.5°	2968.9
25°	2792.5
27.5°	2581.0
30°	2298.9
32.5°	1981.5
35°	1650.1
37.5°	1368.0
40°	1128.2
42.5°	937.9
45°	789.8
47.5°	669.9
50°	585.2
52.5°	514.8
55°	458.4
57.5°	409.0
60°	366.8
62.5°	317.4
65°	282.1
67.5°	239.8
70°	204.5
72.5°	169.2
75°	141.0
77.5°	112.9
80°	84.6
82.5°	63.5
85°	35.2
87.5°	14.1
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)