

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204843

Luminaire Tested: **LE\_6B60D010R EC6B60709040 6LBCSMW1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P204843  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B60D010R EC6B60709040 6LBCSMW1  
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT  
SHALLOW DISTRIBUTION WITH CAST MATTE WHITE TRIM  
SINGLE DRIVER D010TE  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 7114.6 lumens  
Efficiency: N/A  
Efficacy: 113.8 lumens/watt  
Spacing Criteria (0/90/45): 1.23 / 1.23 / 1.33  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 62.5  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P204843

CATALOG NUMBER: LE\_6B60D010R EC6B60709040 6LBSCMW1

### Luminous Intensity Polar Plot





TEST NUMBER: P204843

CATALOG NUMBER: LE\_6B60D010R EC6B60709040 6LBSCMW1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	110	106	102	99	108	104	100	97	100	97	94	96	93	91	92	90	89	87																			
2	101	94	87	82	99	92	86	81	88	84	79	85	81	78	82	79	76	74																			
3	93	83	75	70	90	81	74	69	79	73	68	76	71	67	73	69	65	63																			
4	85	74	66	60	83	73	65	59	70	64	58	68	62	58	66	61	57	55																			
5	79	66	58	52	77	65	57	51	63	56	51	61	55	50	60	54	50	48																			
6	73	60	52	45	71	59	51	45	57	50	45	56	49	44	54	49	44	42																			
7	68	55	46	40	66	54	46	40	52	45	40	51	44	40	50	44	39	37																			
8	63	50	42	36	61	49	41	36	48	41	36	47	40	36	46	40	35	33																			
9	59	46	38	33	57	45	38	32	44	37	32	43	37	32	42	36	32	30																			
10	55	42	35	30	54	42	34	30	41	34	29	40	34	29	39	33	29	27																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P204843

CATALOG NUMBER: LE\_6B60D010R EC6B60709040 6LBSCMW1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	275.3	3.9
10°-20°	783.8	11.0
20°-30°	1179.1	16.6
30°-40°	1397.4	19.6
40°-50°	1390.6	19.5
50°-60°	1121.0	15.8
60°-70°	678.1	9.5
70°-80°	251.8	3.5
80°-90°	37.5	0.5
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2238.2	31.5
0°-40°	3635.5	51.1
0°-60°	6147.1	86.4
0°-90°	7114.6	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	7114.6	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	2906	
5°	2893	275
15°	2776	784
25°	2561	1179
35°	2238	1397
45°	1811	1391
55°	1250	1121
65°	681	678
75°	228	252
85°	30	38
90°	0	



TEST NUMBER: P204843

CATALOG NUMBER: LE\_6B60D010R EC6B60709040 6LBSCMW1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	2905.8
2.5°	2905.8
5°	2892.9
7.5°	2884.2
10°	2858.4
12.5°	2815.2
15°	2776.5
17.5°	2733.4
20°	2681.6
22.5°	2629.9
25°	2560.9
27.5°	2487.6
30°	2405.8
32.5°	2328.1
35°	2237.5
37.5°	2142.8
40°	2030.6
42.5°	1922.9
45°	1810.8
47.5°	1685.8
50°	1547.8
52.5°	1405.5
55°	1250.2
57.5°	1112.2
60°	957.1
62.5°	819.1
65°	681.1
67.5°	551.9
70°	431.1
72.5°	323.4
75°	228.5
77.5°	146.6
80°	86.2
82.5°	51.8
85°	30.1
87.5°	12.9
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)