

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P204429

Luminaire Tested: **LE_6B60D010R EC6B60709040 6LBSGPH1**

Issue Date: 3/3/2020

Test Information

Test Method: LM-41-14
Report Number: P204429
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)
Test Lab: INNOVATION CENTER-P3
Issue Date: 3/3/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LE_6B60D010R EC6B60709040 6LBSGPH1
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT
SHALLOW DISTRIBUTION WITH GRAPHITE HAZE TRIM
SINGLE DRIVER D010TE
Light Source: HIGH LUMEN LED
Ballast/Driver: ELECTRONIC DRIVER

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 6189.4 lumens
Efficiency: N/A
Efficacy: 99.0 lumens/watt
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.26
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 62.5
Input Voltage (V): NR
Input Current (A_{in}): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P204429

CATALOG NUMBER: LE_6B60D010R EC6B60709040 6LBSGPH1

Luminous Intensity Polar Plot





TEST NUMBER: P204429

CATALOG NUMBER: LE_6B60D010R EC6B60709040 6LBSGPH1

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	111	107	103	100	108	105	102	99	101	98	96	97	95	93	93	91	90	88
2	102	95	89	84	100	93	88	83	90	85	82	87	83	80	84	81	78	76
3	94	85	78	72	92	83	77	71	80	75	70	78	73	69	75	71	68	66
4	87	76	68	62	85	75	67	62	72	66	61	70	65	60	68	63	59	57
5	80	68	60	54	78	67	60	54	65	59	53	63	58	53	62	56	52	50
6	74	62	54	48	73	61	53	48	59	52	47	58	52	47	56	51	47	45
7	69	57	48	43	68	56	48	43	54	47	42	53	47	42	52	46	42	40
8	65	52	44	38	63	51	44	38	50	43	38	49	42	38	48	42	38	36
9	60	48	40	35	59	47	40	35	46	39	35	45	39	34	44	38	34	32
10	57	44	37	32	56	44	36	32	43	36	31	42	36	31	41	35	31	30

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P204429

CATALOG NUMBER: LE_6B60D010R EC6B60709040 6LBSGPH1

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	270.6	4.4
10°-20°	759.7	12.3
20°-30°	1108.1	17.9
30°-40°	1263.6	20.4
40°-50°	1212.1	19.6
50°-60°	928.3	15.0
60°-70°	509.4	8.2
70°-80°	135.5	2.2
80°-90°	2.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2138.4	34.6
0°-40°	3402.0	55.0
0°-60°	5542.5	89.5
0°-90°	6189.4	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6189.4	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	2875	
5°	2852	271
15°	2696	760
25°	2407	1108
35°	2020	1264
45°	1575	1212
55°	1040	928
65°	512	509
75°	119	135
85°	0	2
90°	0	



TEST NUMBER: P204429

CATALOG NUMBER: LE_6B60D010R EC6B60709040 6LBSGPH1

CANDELA DISTRIBUTION (FULL):

	0°
0°	2874.6
2.5°	2867.1
5°	2852.4
7.5°	2830.0
10°	2800.4
12.5°	2748.4
15°	2696.4
17.5°	2636.9
20°	2570.1
22.5°	2488.4
25°	2406.6
27.5°	2325.0
30°	2221.0
32.5°	2124.4
35°	2020.4
37.5°	1916.4
40°	1812.4
42.5°	1701.0
45°	1574.8
47.5°	1448.5
50°	1314.8
52.5°	1173.6
55°	1039.9
57.5°	906.2
60°	765.1
62.5°	631.4
65°	512.5
67.5°	393.6
70°	289.8
72.5°	193.1
75°	118.9
77.5°	52.0
80°	14.9
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093





— 0°-180°







(END OF REPORT)