

Scaled data based on original data using

LM-41-14 Approved Method for Photometric Testing Of Indoor Fluorescent Luminaires

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P202576

Luminaire Tested: **LE\_6B60D010R EC6B60709050 6LBSWMH1**

Issue Date: 3/3/2020

**Test Information**

Test Method: LM-41-14  
Report Number: P202576  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P35319)  
Test Lab: INNOVATION CENTER-P3  
Issue Date: 3/3/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LE\_6B60D010R EC6B60709050 6LBSWMH1  
Description: PORTFOLIO 6 INCH SHALLOW RECESSED DOWNLIGHT  
SHALLOW DISTRIBUTION WITH WARM HAZE TRIM  
SINGLE DRIVER D010TE  
Light Source: HIGH LUMEN LED  
Ballast/Driver: ELECTRONIC DRIVER

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 6837.0 lumens  
Efficiency: N/A  
Efficacy: 109.4 lumens/watt  
Spacing Criteria (0/90/45): 0.97 / 0.97 / 1.1  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 62.5  
Input Voltage (V): NR  
Input Current (A<sub>in</sub>): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P202576

CATALOG NUMBER: LE\_6B60D010R EC6B60709050 6LBSWMH1

### Luminous Intensity Polar Plot





TEST NUMBER: P202576

CATALOG NUMBER: LE\_6B60D010R EC6B60709050 6LBSWMH1

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20									20									20									20									
RC	80									50									30									10									0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	50	30	10	0																
RCR																																					
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100																			
1	111	107	104	101	108	105	102	99	101	98	96	97	95	93	94	92	90	88																			
2	103	96	90	85	100	94	89	84	91	86	82	87	84	81	84	81	79	77																			
3	95	86	79	73	92	84	78	73	81	76	71	79	74	70	76	72	69	67																			
4	88	77	70	64	86	76	69	63	74	67	62	71	66	62	69	65	61	59																			
5	81	70	62	56	79	69	61	56	67	60	55	65	59	55	63	58	54	52																			
6	76	64	56	50	74	63	55	50	61	54	49	59	53	49	58	53	48	47																			
7	70	58	50	45	69	57	50	45	56	49	44	55	48	44	53	48	44	42																			
8	66	54	46	40	64	53	45	40	52	45	40	50	44	40	49	44	40	38																			
9	62	49	42	37	61	49	42	37	48	41	37	47	41	36	46	40	36	35																			
10	58	46	39	34	57	45	38	34	45	38	34	44	38	33	43	37	33	32																			

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P202576

CATALOG NUMBER: LE\_6B60D010R EC6B60709050 6LBSWMH1

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	365.8	5.3
10°-20°	956.2	14.0
20°-30°	1267.9	18.5
30°-40°	1352.3	19.8
40°-50°	1264.2	18.5
50°-60°	963.9	14.1
60°-70°	524.3	7.7
70°-80°	140.7	2.1
80°-90°	1.7	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2589.9	37.9
0°-40°	3942.2	57.7
0°-60°	6170.3	90.2
0°-90°	6837.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	6837.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	3954	
5°	3899	366
15°	3409	956
25°	2760	1268
35°	2161	1352
45°	1646	1264
55°	1085	964
65°	524	524
75°	122	141
85°	0	2
90°	0	



TEST NUMBER: P202576

CATALOG NUMBER: LE\_6B60D010R EC6B60709050 6LBSWMH1

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	3953.6
2.5°	3941.0
5°	3899.1
7.5°	3811.2
10°	3710.6
12.5°	3568.2
15°	3409.1
17.5°	3250.0
20°	3078.2
22.5°	2915.0
25°	2760.0
27.5°	2596.6
30°	2441.6
32.5°	2290.9
35°	2161.1
37.5°	2031.2
40°	1897.2
42.5°	1775.8
45°	1645.9
47.5°	1503.5
50°	1369.5
52.5°	1227.1
55°	1084.8
57.5°	929.8
60°	787.4
62.5°	653.4
65°	523.5
67.5°	406.2
70°	297.4
72.5°	205.2
75°	121.5
77.5°	54.5
80°	12.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0



Report Generated By E9808895 / USPTCWHP6082093







— 0°-180°







(END OF REPORT)