

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for

Cooper Lighting Solutions

(formerly Eaton)

Brand: PORTFOLIO

Report Number: P843891

Luminaire Tested: **LD6C08DE010B35 EU6C08B35 6LBWH**

Issue Date: 2/17/2023

Test Information

Test Method: LM-79-08
Report Number: P843891
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (P202739)
Test Lab: INNOVATION CENTER
Issue Date: 2/17/2023
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LD6C08DE010B35 EU6C08B35 6LBWH
Description:
Light Source: -
Ballast/Driver:

Summary


Lumens per Lamp: N/A
Luminaire Lumens: 744.7 lumens
Efficiency: N/A
Efficacy: 77.6 lumens/watt
Spacing Criteria (0/90/45): 1.16 / 1.16 / 1.16
Luminous Opening: Circular (Dia: 0.5' x H: 0')
CIE Type: Direct

Input Watts (W): 9.6
Input Voltage (V):
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT

TEST NUMBER: P843891

CATALOG NUMBER: LD6C08DE010B35 EU6C08B35 6LBWH

Luminous Intensity Polar Plot





TEST NUMBER: P843891

CATALOG NUMBER: LD6C08DE010B35 EU6C08B35 6LBWH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

| | | | | | | | | | | | | | | | | | | | | | |
|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|-----|----|----|-----|
| RF | 20 | | | | 20 | | | | 20 | | | | 20 | | | | 20 | | | | |
| RC | 80 | | | | 70 | | | | 50 | | | | 30 | | | | 10 | | | 0 | |
| RW | 70 | 50 | 30 | 10 | 70 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 50 | 30 | 10 | 0 |
| RCR | | | | | | | | | | | | | | | | | | | | | |
| 0 | 119 | 119 | 119 | 119 | 116 | 116 | 116 | 116 | 111 | 111 | 111 | 106 | 106 | 106 | 102 | 102 | 102 | 100 | | | 100 |
| 1 | 112 | 109 | 106 | 103 | 110 | 107 | 104 | 101 | 103 | 100 | 98 | 99 | 97 | 95 | 95 | 94 | 93 | 91 | | | 91 |
| 2 | 105 | 99 | 94 | 90 | 103 | 97 | 93 | 89 | 94 | 90 | 87 | 91 | 88 | 85 | 88 | 85 | 83 | 81 | | | 81 |
| 3 | 98 | 90 | 84 | 79 | 96 | 89 | 83 | 78 | 86 | 81 | 77 | 83 | 79 | 76 | 81 | 78 | 75 | 73 | | | 73 |
| 4 | 92 | 82 | 75 | 70 | 90 | 81 | 75 | 70 | 79 | 73 | 69 | 77 | 72 | 68 | 75 | 71 | 67 | 65 | | | 65 |
| 5 | 86 | 75 | 68 | 63 | 84 | 74 | 68 | 63 | 72 | 66 | 62 | 71 | 65 | 61 | 69 | 64 | 61 | 59 | | | 59 |
| 6 | 80 | 69 | 62 | 57 | 78 | 68 | 61 | 56 | 67 | 61 | 56 | 65 | 60 | 56 | 64 | 59 | 55 | 53 | | | 53 |
| 7 | 75 | 64 | 56 | 51 | 73 | 63 | 56 | 51 | 62 | 55 | 51 | 60 | 55 | 51 | 59 | 54 | 50 | 49 | | | 49 |
| 8 | 70 | 59 | 52 | 47 | 69 | 58 | 51 | 47 | 57 | 51 | 46 | 56 | 50 | 46 | 55 | 50 | 46 | 44 | | | 44 |
| 9 | 66 | 55 | 48 | 43 | 65 | 54 | 47 | 43 | 53 | 47 | 43 | 52 | 47 | 42 | 51 | 46 | 42 | 41 | | | 41 |
| 10 | 62 | 51 | 44 | 40 | 61 | 50 | 44 | 39 | 50 | 43 | 39 | 49 | 43 | 39 | 48 | 43 | 39 | 38 | | | 38 |

AVERAGE LUMINANCE (cd/sqm):

| | |
|-----|-------|
| | 0° |
| 0° | 25173 |
| 5° | 25165 |
| 10° | 24972 |
| 15° | 24802 |
| 20° | 24426 |
| 25° | 23868 |
| 30° | 22472 |
| 35° | 20345 |
| 40° | 16982 |
| 45° | 13009 |
| 50° | 9219 |
| 55° | 5811 |
| 60° | 3278 |
| 65° | 2127 |
| 70° | 1394 |
| 75° | 1038 |
| 80° | 600 |
| 85° | 629 |



TEST NUMBER: P843891

CATALOG NUMBER: LD6C08DE010B35 EU6C08B35 6LBWH

ZONAL LUMENS:

| Zone | Lumens | % Fixture |
|-----------|--------|-----------|
| 0°-10° | 43.4 | 5.8 |
| 10°-20° | 123.1 | 16.5 |
| 20°-30° | 180.5 | 24.2 |
| 30°-40° | 187.8 | 25.2 |
| 40°-50° | 129.9 | 17.4 |
| 50°-60° | 56.6 | 7.6 |
| 60°-70° | 17.4 | 2.3 |
| 70°-80° | 5.2 | 0.7 |
| 80°-90° | 0.8 | 0.1 |
| 90°-100° | 0.0 | 0.0 |
| 100°-110° | 0.0 | 0.0 |
| 110°-120° | 0.0 | 0.0 |
| 120°-130° | 0.0 | 0.0 |
| 130°-140° | 0.0 | 0.0 |
| 140°-150° | 0.0 | 0.0 |
| 150°-160° | 0.0 | 0.0 |
| 160°-170° | 0.0 | 0.0 |
| 170°-180° | 0.0 | 0.0 |
| 0°-30° | 346.9 | 46.6 |
| 0°-40° | 534.7 | 71.8 |
| 0°-60° | 721.3 | 96.9 |
| 0°-90° | 744.7 | 100.0 |
| 90°-120° | 0.0 | 0.0 |
| 90°-150° | 0.0 | 0.0 |
| 90°-180° | 0.0 | 0.0 |
| 0°-180° | 744.7 | 100.0 |

CANDELA DISTRIBUTION:

| | 0° | Flux |
|-----|-----|------|
| 0° | 459 | |
| 5° | 457 | 43 |
| 15° | 437 | 123 |
| 25° | 395 | 180 |
| 35° | 304 | 188 |
| 45° | 168 | 130 |
| 55° | 61 | 57 |
| 65° | 16 | 17 |
| 75° | 5 | 5 |
| 85° | 1 | 1 |
| 90° | 0 | |



TEST NUMBER: P843891

CATALOG NUMBER: LD6C08DE010B35 EU6C08B35 6LBWH

CANDELA DISTRIBUTION (FULL):

| | 0° |
|-------|-------|
| 0° | 459.2 |
| 2.5° | 460.2 |
| 5° | 457.3 |
| 7.5° | 453.5 |
| 10° | 448.6 |
| 12.5° | 443.8 |
| 15° | 437.0 |
| 17.5° | 428.3 |
| 20° | 418.7 |
| 22.5° | 408.1 |
| 25° | 394.6 |
| 27.5° | 377.3 |
| 30° | 355.0 |
| 32.5° | 331.9 |
| 35° | 304.0 |
| 37.5° | 273.1 |
| 40° | 237.3 |
| 42.5° | 201.7 |
| 45° | 167.8 |
| 47.5° | 136.0 |
| 50° | 108.1 |
| 52.5° | 82.1 |
| 55° | 60.8 |
| 57.5° | 43.5 |
| 60° | 29.9 |
| 62.5° | 22.2 |
| 65° | 16.4 |
| 67.5° | 12.6 |
| 70° | 8.7 |
| 72.5° | 6.8 |
| 75° | 4.9 |
| 77.5° | 2.9 |
| 80° | 1.9 |
| 82.5° | 1.0 |
| 85° | 1.0 |
| 87.5° | 0.0 |
| 90° | 0.0 |



Report Generated By 670246072 / DESKTOP-50001EG





— 0°-180°







(END OF REPORT)