

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P243936

Luminaire Tested: **LSR8B10D010 EC8B10930 8LBN0LI**

Issue Date: 03/03/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P243936  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-10)  
Test Lab: INNOVATION CENTER(G1)  
Issue Date: 03/03/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LSR8B10D010 EC8B10930 8LBNOLI  
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED  
DOWNLIGHT- CYLINDEC  
97 CRI 3000 CCT WITH SPECULAR CLEAR TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 914.8 lumens  
Efficiency: N/A  
Efficacy: 89.7 lumens/watt  
Spacing Criteria (0/90/45): 0.25 / 0.25 / 0.32  
Luminous Opening: Point Source (0' x 0' x 0')  
CIE Type: Direct


Input Watts (W): 10.2  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P243936

CATALOG NUMBER: LSR8B10D010 EC8B10930 8LBNOLI

### Luminous Intensity Polar Plot





TEST NUMBER: P243936

CATALOG NUMBER: LSR8B10D010 EC8B10930 8LBNOLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		99	98	97	95
2	110	106	102	100	108	104	101	99	101	99	96		98	96	94		95	94	92	91
3	106	100	96	93	104	99	95	92	96	93	91		94	92	89		92	90	88	87
4	102	95	91	87	100	94	90	87	92	89	86		90	87	85		89	86	84	83
5	98	91	86	83	96	90	86	82	88	85	82		87	84	81		85	83	80	79
6	94	87	82	79	93	86	82	78	85	81	78		83	80	77		82	79	77	76
7	91	83	78	75	90	83	78	75	81	77	74		80	77	74		79	76	74	72
8	88	80	75	72	86	79	75	71	78	74	71		77	74	71		76	73	71	70
9	85	77	72	69	84	76	72	69	75	71	68		75	71	68		74	70	68	67
10	82	74	69	66	81	73	69	66	73	69	66		72	68	66		71	68	65	64

**AVERAGE LUMINANCE (cd/sqm):**





TEST NUMBER: P243936

CATALOG NUMBER: LSR8B10D010 EC8B10930 8LBNOLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	248.6	27.2
10°-20°	288.8	31.6
20°-30°	249.3	27.3
30°-40°	108.1	11.8
40°-50°	17.0	1.9
50°-60°	1.2	0.1
60°-70°	0.6	0.1
70°-80°	0.7	0.1
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	786.7	86.0
0°-40°	894.9	97.8
0°-60°	913.1	99.8
0°-90°	914.8	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	914.8	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	4482	
5°	3101	249
15°	1001	289
25°	549	249
35°	153	108
45°	18	17
55°	1	1
65°	1	1
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P243936

CATALOG NUMBER: LSR8B10D010 EC8B10930 8LBNOLI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	4481.6
2.5°	4047.0
5°	3100.9
7.5°	2211.5
10°	1613.1
12.5°	1237.7
15°	1001.1
17.5°	841.9
20°	723.7
22.5°	622.9
25°	548.7
27.5°	470.6
30°	377.6
32.5°	262.4
35°	153.2
37.5°	85.6
40°	50.0
42.5°	31.1
45°	17.7
47.5°	14.2
50°	3.7
52.5°	1.9
55°	1.2
57.5°	0.7
60°	0.0
62.5°	0.3
65°	1.2
67.5°	0.9
70°	0.3
72.5°	1.6
75°	0.7
77.5°	0.0
80°	0.7
82.5°	0.3
85°	0.0
87.5°	0.7
90°	0.0

(END OF REPORT)