

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245574

Luminaire Tested: **LSR8B10D010 EC8B10940 8LBW0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245574
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-46)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B10D010 EC8B10940 8LBW0GPH
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
90 CRI 4000 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 906.0 lumens
Efficiency: N/A
Efficacy: 88.8 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.05
Luminous Opening: Circular (Dia: 0.67' x H: 0')
CIE Type: Direct


Input Watts (W): 10.2
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245574

CATALOG NUMBER: LSR8B10D010 EC8B10940 8LBW0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245574

CATALOG NUMBER: LSR8B10D010 EC8B10940 8LBW0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	113	110	107	104	110	108	105	103	103	101	100	100	98	97	96	95	94	92
2	106	101	96	92	104	99	95	91	96	92	89	93	90	87	90	88	86	84
3	100	93	87	83	98	91	86	82	89	84	81	86	82	79	84	81	78	76
4	94	85	79	74	92	84	78	74	82	77	73	80	76	72	78	74	71	70
5	88	79	72	67	87	78	72	67	76	71	66	74	70	66	73	69	65	64
6	83	73	66	61	82	72	66	61	71	65	61	69	64	60	68	63	60	58
7	78	68	61	56	77	67	61	56	66	60	56	65	59	56	63	59	55	54
8	74	63	56	52	73	63	56	52	61	56	51	60	55	51	59	55	51	49
9	70	59	52	48	69	58	52	48	57	52	48	57	51	47	56	51	47	46
10	66	55	49	44	65	55	49	44	54	48	44	53	48	44	52	47	44	43

AVERAGE LUMINANCE (cd/sqm):

	0°
0°	21755
5°	21241
10°	20575
15°	20275
20°	20037
25°	19608
30°	18366
35°	14997
40°	8952
45°	5377
50°	3876
55°	2640
60°	1653
65°	810
70°	207
75°	83
80°	53
85°	0



TEST NUMBER: P245574

CATALOG NUMBER: LSR8B10D010 EC8B10940 8LBW0GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	64.6	7.1
10°-20°	179.2	19.8
20°-30°	263.2	29.1
30°-40°	238.6	26.3
40°-50°	102.1	11.3
50°-60°	45.2	5.0
60°-70°	12.0	1.3
70°-80°	0.9	0.1
80°-90°	0.0	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	507.0	56.0
0°-40°	745.6	82.3
0°-60°	893.0	98.6
0°-90°	906.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	906.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	706	
5°	686	65
15°	635	179
25°	576	263
35°	398	239
45°	123	102
55°	49	45
65°	11	12
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P245574

CATALOG NUMBER: LSR8B10D010 EC8B10940 8LBW0GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	705.5
2.5°	699.9
5°	686.2
7.5°	670.5
10°	657.1
12.5°	645.9
15°	635.1
17.5°	623.7
20°	610.6
22.5°	595.2
25°	576.3
27.5°	550.8
30°	515.8
32.5°	466.7
35°	398.4
37.5°	308.7
40°	222.4
42.5°	160.6
45°	123.3
47.5°	99.4
50°	80.8
52.5°	64.1
55°	49.1
57.5°	36.6
60°	26.8
62.5°	18.6
65°	11.1
67.5°	4.9
70°	2.3
72.5°	1.3
75°	0.7
77.5°	0.3
80°	0.3
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)