

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P243924

Luminaire Tested: **LSR8B10D010 EC8B10950 8LBN0LI**

Issue Date: 03/03/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P243924  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-10)  
Test Lab: INNOVATION CENTER(G1)  
Issue Date: 03/03/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LSR8B10D010 EC8B10950 8LBNOLI  
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED  
DOWNLIGHT- CYLINDEC  
90 CRI 5000 CCT WITH SPECULAR CLEAR TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 1022.0 lumens  
Efficiency: N/A  
Efficacy: 100.2 lumens/watt  
Spacing Criteria (0/90/45): 0.25 / 0.25 / 0.32  
Luminous Opening: Circular (Dia: 0.67' x H: 0')  
CIE Type: Direct


Input Watts (W): 10.2  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P243924

CATALOG NUMBER: LSR8B10D010 EC8B10950 8LBN0LI

### Luminous Intensity Polar Plot





TEST NUMBER: P243924

CATALOG NUMBER: LSR8B10D010 EC8B10950 8LBNOLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103		102	101	100		99	98	97	95
2	110	106	102	100	108	104	101	99	101	99	96		98	96	94		95	94	92	91
3	106	100	96	93	104	99	95	92	96	93	91		94	92	89		92	90	88	87
4	102	95	91	87	100	94	90	87	92	89	86		90	87	85		89	86	84	83
5	98	91	86	83	96	90	86	82	88	85	82		87	84	81		85	83	80	79
6	94	87	82	79	93	86	82	78	85	81	78		83	80	77		82	79	77	76
7	91	83	78	75	90	83	78	75	81	77	74		80	77	74		79	76	74	72
8	88	80	75	72	86	79	75	71	78	74	71		77	74	71		76	73	71	70
9	85	77	72	69	84	76	72	69	75	71	68		75	71	68		74	70	68	67
10	82	74	69	66	81	73	69	66	73	69	66		72	68	66		71	68	65	64

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	154401
5°	107240
10°	56431
15°	35704
20°	26534
25°	20860
30°	15019
35°	6445
40°	2246
45°	863
50°	201
55°	75
60°	0
65°	102
70°	27
75°	83
80°	124
85°	0



TEST NUMBER: P243924

CATALOG NUMBER: LSR8B10D010 EC8B10950 8LBNOLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	277.7	27.2
10°-20°	322.7	31.6
20°-30°	278.5	27.3
30°-40°	120.8	11.8
40°-50°	19.0	1.9
50°-60°	1.4	0.1
60°-70°	0.7	0.1
70°-80°	0.8	0.1
80°-90°	0.4	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	879.0	86.0
0°-40°	999.8	97.8
0°-60°	1020.1	99.8
0°-90°	1022.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1022.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	5007	
5°	3464	278
15°	1118	323
25°	613	279
35°	171	121
45°	20	19
55°	1	1
65°	1	1
75°	1	1
85°	0	0
90°	0	



TEST NUMBER: P243924

CATALOG NUMBER: LSR8B10D010 EC8B10950 8LBNOLI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	5007.1
2.5°	4521.6
5°	3464.5
7.5°	2470.8
10°	1802.2
12.5°	1382.9
15°	1118.4
17.5°	940.6
20°	808.6
22.5°	695.9
25°	613.1
27.5°	525.8
30°	421.8
32.5°	293.2
35°	171.2
37.5°	95.7
40°	55.8
42.5°	34.7
45°	19.8
47.5°	15.9
50°	4.2
52.5°	2.1
55°	1.4
57.5°	0.7
60°	0.0
62.5°	0.3
65°	1.4
67.5°	1.0
70°	0.3
72.5°	1.7
75°	0.7
77.5°	0.0
80°	0.7
82.5°	0.3
85°	0.0
87.5°	0.7
90°	0.0

(END OF REPORT)