

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245803

Luminaire Tested: **LSR8B15D010 EC8B159727 8LBS0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245803
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-16)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B15D010 EC8B159727 8LBS0GPH
Description: PORTFOLIO 8 INCH WIDE SHALLOW DISTRIBUTION 75 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
97 CRI 2700 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1062.0 lumens
Efficiency: N/A
Efficacy: 73.8 lumens/watt
Spacing Criteria (0/90/45): 1.19 / 1.19 / 1.25
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 14.4
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245803

CATALOG NUMBER: LSR8B15D010 EC8B159727 8LBS0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245803

CATALOG NUMBER: LSR8B15D010 EC8B159727 8LBS0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	112	109	106	103	110	107	104	102	103	100	98		99	97	95		95	94	93	91
2	105	99	94	90	103	97	93	89	94	90	87		91	88	85		88	85	83	81
3	98	90	84	79	96	88	83	78	86	81	77		83	79	76		81	77	74	73
4	91	82	75	70	89	81	74	69	78	73	69		76	72	68		74	70	67	65
5	85	75	68	62	83	74	67	62	72	66	61		70	65	61		68	64	60	58
6	79	69	61	56	78	68	61	56	66	60	55		64	59	55		63	58	54	53
7	74	63	56	50	73	62	55	50	61	55	50		59	54	50		58	53	49	48
8	70	58	51	46	68	57	50	46	56	50	45		55	49	45		54	49	45	43
9	65	54	47	42	64	53	46	42	52	46	41		51	45	41		50	45	41	40
10	62	50	43	38	60	49	43	38	48	42	38		48	42	38		47	42	38	36

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P245803

CATALOG NUMBER: LSR8B15D010 EC8B159727 8LBS0GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	57.4	5.4
10°-20°	162.3	15.3
20°-30°	241.5	22.7
30°-40°	274.6	25.9
40°-50°	224.5	21.1
50°-60°	83.7	7.9
60°-70°	15.3	1.4
70°-80°	2.4	0.2
80°-90°	0.3	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	461.2	43.4
0°-40°	735.8	69.3
0°-60°	1044.0	98.3
0°-90°	1062.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1062.0	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	610	
5°	605	57
15°	575	162
25°	525	242
35°	441	275
45°	299	225
55°	86	84
65°	14	15
75°	2	2
85°	0	0
90°	0	



TEST NUMBER: P245803

CATALOG NUMBER: LSR8B15D010 EC8B159727 8LBS0GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	609.6
2.5°	608.5
5°	605.4
7.5°	599.9
10°	592.6
12.5°	584.3
15°	575.3
17.5°	564.9
20°	553.8
22.5°	540.6
25°	525.4
27.5°	508.0
30°	488.3
32.5°	465.8
35°	440.8
37.5°	414.1
40°	383.3
42.5°	345.2
45°	298.7
47.5°	242.9
50°	184.4
52.5°	130.0
55°	85.9
57.5°	54.1
60°	33.6
62.5°	21.5
65°	13.9
67.5°	8.0
70°	4.5
72.5°	2.8
75°	2.1
77.5°	1.4
80°	1.0
82.5°	0.3
85°	0.3
87.5°	0.0
90°	0.0

(END OF REPORT)