

Scaled data based on original data using
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State
Lighting Products

Test Report Prepared for
Cooper Lighting Solutions
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P245594

Luminaire Tested: **LSR8B20D010 EC8B20930 8LBW0GPH**

Issue Date: 03/03/2020

Test Information

Test Method: LM-79-08
Report Number: P245594
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-46)
Test Lab: INNOVATION CENTER(G1)
Issue Date: 03/03/2020
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)
Product Line: PORTFOLIO
Catalog Number: LSR8B20D010 EC8B20930 8LBW0GPH
Description: PORTFOLIO 8 INCH WIDE DISTRIBUTION 60 DEGREE CUTOFF RECESSED
DOWNLIGHT- CYLINDEC
97 CRI 3000 CCT WITH GRAPHITE TRIM
Light Source: -
Ballast/Driver: -

Summary

Lumens per Lamp: N/A
Luminaire Lumens: 1616.5 lumens
Efficiency: N/A
Efficacy: 75.9 lumens/watt
Spacing Criteria (0/90/45): 1.11 / 1.11 / 1.05
Luminous Opening: Point Source (0' x 0' x 0')
CIE Type: Direct


Input Watts (W): 21.3
Input Voltage (V): NR
Input Current (Ain): NR
Voltage Rise (V): NR
Power Factor: NR
Total Harmonic Distortion (THDi): NR
Frequency (hertz): 60
Stabilization Time: NR
Operation Time: NR
Ambient Temperature (°C): NR
Test Distance: 25 FT



TEST NUMBER: P245594

CATALOG NUMBER: LSR8B20D010 EC8B20930 8LBW0GPH

Luminous Intensity Polar Plot





TEST NUMBER: P245594

CATALOG NUMBER: LSR8B20D010 EC8B20930 8LBW0GPH

COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:

RF	20				20				20				20				20			
RC	80				70				50				30				10	0		
RW	70	50	30	10	70	50	30	10	50	30	10		50	30	10		50	30	10	0
RCR																				
0	119	119	119	119	116	116	116	116	111	111	111		106	106	106		102	102	102	100
1	113	110	107	104	110	108	105	103	103	101	100		100	98	97		96	95	94	92
2	106	101	96	92	104	99	95	91	96	92	89		93	90	87		90	88	86	84
3	100	93	87	83	98	91	86	82	89	84	81		86	82	79		84	81	78	76
4	94	85	79	74	92	84	78	74	82	77	73		80	76	72		78	74	71	70
5	88	79	72	67	87	78	72	67	76	71	66		74	70	66		73	69	65	64
6	83	73	66	61	82	72	66	61	71	65	61		69	64	60		68	63	60	58
7	78	68	61	56	77	67	61	56	66	60	56		65	59	56		63	59	55	54
8	74	63	56	52	73	63	56	52	61	56	51		60	55	51		59	55	51	49
9	70	59	52	48	69	58	52	48	57	52	48		57	51	47		56	51	47	46
10	66	55	49	44	65	55	49	44	54	48	44		53	48	44		52	47	44	43

AVERAGE LUMINANCE (cd/sqm):





TEST NUMBER: P245594

CATALOG NUMBER: LSR8B20D010 EC8B20930 8LBW0GPH

ZONAL LUMENS:

Zone	Lumens	% Fixture
0°-10°	115.2	7.1
10°-20°	319.8	19.8
20°-30°	469.6	29.1
30°-40°	425.7	26.3
40°-50°	182.2	11.3
50°-60°	80.7	5.0
60°-70°	21.5	1.3
70°-80°	1.7	0.1
80°-90°	0.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	904.6	56.0
0°-40°	1330.3	82.3
0°-60°	1593.2	98.6
0°-90°	1616.5	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	1616.5	100.0

CANDELA DISTRIBUTION:

	0°	Flux
0°	1259	
5°	1224	115
15°	1133	320
25°	1028	470
35°	711	426
45°	220	182
55°	88	81
65°	20	21
75°	1	2
85°	0	0
90°	0	



TEST NUMBER: P245594

CATALOG NUMBER: LSR8B20D010 EC8B20930 8LBW0GPH

CANDELA DISTRIBUTION (FULL):

	0°
0°	1258.7
2.5°	1248.8
5°	1224.2
7.5°	1196.2
10°	1172.3
12.5°	1152.5
15°	1133.2
17.5°	1112.8
20°	1089.5
22.5°	1062.0
25°	1028.2
27.5°	982.7
30°	920.2
32.5°	832.7
35°	710.7
37.5°	550.9
40°	396.8
42.5°	286.5
45°	219.9
47.5°	177.3
50°	144.2
52.5°	114.3
55°	87.6
57.5°	65.4
60°	47.9
62.5°	33.3
65°	19.8
67.5°	8.7
70°	4.0
72.5°	2.4
75°	1.1
77.5°	0.6
80°	0.6
82.5°	0.0
85°	0.0
87.5°	0.0
90°	0.0

(END OF REPORT)