

Scaled data based on original data using  
LM-79-08 Approved Method: Electrical and Photometric Measurements of Solid-State  
Lighting Products

Test Report Prepared for  
Cooper Lighting Solutions  
(formerly Eaton)

Brand: PORTFOLIO

Report Number: P243891

Luminaire Tested: **LSR8B30D010 EC8B30840 8LBN0LI**

Issue Date: 03/03/2020

**Test Information**

Test Method: LM-79-08  
Report Number: P243891  
TEST IS SCALED FROM IESNA LM-79-08 TEST DATA (G1-1801-521-10)  
Test Lab: INNOVATION CENTER(G1)  
Issue Date: 03/03/2020  
Manufacturer: COOPER LIGHTING SOLUTIONS (FORMERLY EATON)  
Product Line: PORTFOLIO  
Catalog Number: LSR8B30D010 EC8B30840 8LBNOLI  
Description: PORTFOLIO 8 INCH NARROW DISTRIBUTION 50 DEGREE CUTOFF RECESSED  
DOWNLIGHT- CYLINDEC  
80 CRI 4000 CCT WITH SPECULAR CLEAR TRIM  
Light Source: -  
Ballast/Driver: -

**Summary**

Lumens per Lamp: N/A  
Luminaire Lumens: 2930.0 lumens  
Efficiency: N/A  
Efficacy: 108.1 lumens/watt  
Spacing Criteria (0/90/45): 0.25 / 0.25 / 0.32  
Luminous Opening: Circular (Dia: 0.67' x H: 0')  
CIE Type: Direct


Input Watts (W): 27.1  
Input Voltage (V): NR  
Input Current (Ain): NR  
Voltage Rise (V): NR  
Power Factor: NR  
Total Harmonic Distortion (THDi): NR  
Frequency (hertz): 60  
Stabilization Time: NR  
Operation Time: NR  
Ambient Temperature (°C): NR  
Test Distance: 25 FT



TEST NUMBER: P243891

CATALOG NUMBER: LSR8B30D010 EC8B30840 8LBNOLI

### Luminous Intensity Polar Plot





TEST NUMBER: P243891

CATALOG NUMBER: LSR8B30D010 EC8B30840 8LBNOLI

**COEFFICIENT OF UTILIZATION - ZONAL CAVITY METHOD:**

RF	20				20				20				20				20	
RC	80				70				50				30				10	0
RW	70	50	30	10	70	50	30	10	50	30	10	50	30	10	50	30	10	0
RCR																		
0	119	119	119	119	116	116	116	116	111	111	111	106	106	106	102	102	102	100
1	114	112	110	108	112	110	108	106	106	104	103	102	101	100	99	98	97	95
2	110	106	102	100	108	104	101	99	101	99	96	98	96	94	95	94	92	91
3	106	100	96	93	104	99	95	92	96	93	91	94	92	89	92	90	88	87
4	102	95	91	87	100	94	90	87	92	89	86	90	87	85	89	86	84	83
5	98	91	86	83	96	90	86	82	88	85	82	87	84	81	85	83	80	79
6	94	87	82	79	93	86	82	78	85	81	78	83	80	77	82	79	77	76
7	91	83	78	75	90	83	78	75	81	77	74	80	77	74	79	76	74	72
8	88	80	75	72	86	79	75	71	78	74	71	77	74	71	76	73	71	70
9	85	77	72	69	84	76	72	69	75	71	68	75	71	68	74	70	68	67
10	82	74	69	66	81	73	69	66	73	69	66	72	68	66	71	68	65	64

**AVERAGE LUMINANCE (cd/sqm):**

	0°
0°	442658
5°	307449
10°	161786
15°	102365
20°	76072
25°	59804
30°	43059
35°	18480
40°	6441
45°	2468
50°	571
55°	215
60°	0
65°	292
70°	90
75°	238
80°	355
85°	0



TEST NUMBER: P243891

CATALOG NUMBER: LSR8B30D010 EC8B30840 8LBNOLI

**ZONAL LUMENS:**

Zone	Lumens	% Fixture
0°-10°	796.3	27.2
10°-20°	925.2	31.6
20°-30°	798.5	27.3
30°-40°	346.4	11.8
40°-50°	54.3	1.9
50°-60°	3.9	0.1
60°-70°	2.1	0.1
70°-80°	2.2	0.1
80°-90°	1.1	0.0
90°-100°	0.0	0.0
100°-110°	0.0	0.0
110°-120°	0.0	0.0
120°-130°	0.0	0.0
130°-140°	0.0	0.0
140°-150°	0.0	0.0
150°-160°	0.0	0.0
160°-170°	0.0	0.0
170°-180°	0.0	0.0
0°-30°	2519.9	86.0
0°-40°	2866.4	97.8
0°-60°	2924.6	99.8
0°-90°	2930.0	100.0
90°-120°	0.0	0.0
90°-150°	0.0	0.0
90°-180°	0.0	0.0
0°-180°	2930.0	100.0

**CANDELA DISTRIBUTION:**

	0°	Flux
0°	14355	
5°	9932	796
15°	3206	925
25°	1758	798
35°	491	346
45°	57	54
55°	4	4
65°	4	2
75°	2	2
85°	0	1
90°	0	



TEST NUMBER: P243891

CATALOG NUMBER: LSR8B30D010 EC8B30840 8LBNOLI

**CANDELA DISTRIBUTION (FULL):**

	0°
0°	14355.1
2.5°	12963.0
5°	9932.4
7.5°	7083.6
10°	5166.9
12.5°	3964.6
15°	3206.5
17.5°	2696.7
20°	2318.2
22.5°	1995.2
25°	1757.7
27.5°	1507.3
30°	1209.3
32.5°	840.6
35°	490.9
37.5°	274.2
40°	160.0
42.5°	99.4
45°	56.6
47.5°	45.7
50°	11.9
52.5°	6.0
55°	4.0
57.5°	2.0
60°	0.0
62.5°	1.0
65°	4.0
67.5°	3.0
70°	1.0
72.5°	5.0
75°	2.0
77.5°	0.0
80°	2.0
82.5°	1.0
85°	0.0
87.5°	2.0
90°	0.0

(END OF REPORT)